

Laboratory Certification ID	Laboratory Name	City/State	Laboratory Certification ID (Laboratory Performing Sample Analysis)	School Name	County	School Type (Code)	School ID	Laboratory Reporting Date	Laboratory Sample ID	School Outlet ID/Floor Plan ID	Building #	Building Name	Building Address	Floor #	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Use (code)	Sample Tap/Outlet Description/Location	Sample Volume (mL)	Sample Type (Code)	Date Water Last Used	Time Water Last Used	Date Sample Collected	Time Sample Collected	Sampler Name	Sampler Telephone number	Analysis Date	Analysis Method	Detection Limit (ppb)	Lead Sample Result (ppb)	≥ 20.5 ppb AL?	Notes
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Barstow Elementary	Calvert	P	04-028	5/17/2018	K20224	67	1	Main Building	295 JW Williams Rd, Prince Fredrick MD 20678	2	CS	CO	faucet in 220	250	FD	4/17/2018	7:00:00 PM	4/18/2018	6:30:00 AM	Chris Mlinaric	410-535-1800	4/22/2018	200.9	1	1.70	no	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Barstow Elementary	Calvert	P	04-028	5/17/2018	K20225	b68	1	Main Building	295 JW Williams Rd, Prince Fredrick MD 20678	2	CF	CO	bubbler in 215	250	FD	4/17/2018	7:00:00 PM	4/18/2018	6:34:00 AM	Chris Mlinaric	410-535-1800	4/22/2018	200.9	1	1.00	no	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Barstow Elementary	Calvert	P	04-028	5/17/2018	K20226	69	1	Main Building	295 JW Williams Rd, Prince Fredrick MD 20678	2	CS	CO	faucet in 215	250	FD	4/17/2018	7:00:00 PM	4/18/2018	6:35:00 AM	Chris Mlinaric	410-535-1800	4/22/2018	200.9	1	2.50	no	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Barstow Elementary	Calvert	P	04-028	5/17/2018	K20227	b70	1	Main Building	295 JW Williams Rd, Prince Fredrick MD 20678	2	CF	CO	bubbler in 214	250	FD	4/17/2018	7:00:00 PM	4/18/2018	6:35:00 AM	Chris Mlinaric	410-535-1800	4/22/2018	200.9	1	1.00	no	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Barstow Elementary	Calvert	P	04-028	5/17/2018	K20228	71	1	Main Building	295 JW Williams Rd, Prince Fredrick MD 20678	2	CS	CO	faucet in 214	250	FD	4/17/2018	7:00:00 PM	4/18/2018	6:35:00 AM	Chris Mlinaric	410-535-1800	4/22/2018	200.9	1	2.60	no	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Barstow Elementary	Calvert	P	04-028	5/17/2018	K20229	b72	1	Main Building	295 JW Williams Rd, Prince Fredrick MD 20678	2	CF	CO	bubbler in 213	250	FD	4/17/2018	7:00:00 PM	4/18/2018	6:37:00 AM	Chris Mlinaric	410-535-1800	4/22/2018	200.9	1	<1.0	no	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Barstow Elementary	Calvert	P	04-028	5/17/2018	K20230	73	1	Main Building	295 JW Williams Rd, Prince Fredrick MD 20678	2	CS	CO	faucet in 213	250	FD	4/17/2018	7:00:00 PM	4/18/2018	6:37:00 AM	Chris Mlinaric	410-535-1800	4/22/2018	200.9	1	1.90	no	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Barstow Elementary	Calvert	P	04-028	5/17/2018	K20231	b74	1	Main Building	295 JW Williams Rd, Prince Fredrick MD 20678	2	CF	CO	bubbler in 212	250	FD	4/17/2018	7:00:00 PM	4/18/2018	6:38:00 AM	Chris Mlinaric	410-535-1800	4/22/2018	200.9	1	<1.0	no	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Barstow Elementary	Calvert	P	04-028	5/17/2018	K20232	75	1	Main Building	295 JW Williams Rd, Prince Fredrick MD 20678	2	CS	CO	faucet in 212	250	FD	4/17/2018	7:00:00 PM	4/18/2018	6:38:00 AM	Chris Mlinaric	410-535-1800	4/22/2018	200.9	1	1.50	no	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Barstow Elementary	Calvert	P	04-028	5/17/2018	K20233	b76	1	Main Building	295 JW Williams Rd, Prince Fredrick MD 20678	2	CF	CO	bubbler in 211	250	FD	4/17/2018	7:00:00 PM	4/18/2018	6:52:00 AM	Chris Mlinaric	410-535-1800	4/22/2018	200.9	1	1.00	no	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Barstow Elementary	Calvert	P	04-028	5/17/2018	K20234	77	1	Main Building	295 JW Williams Rd, Prince Fredrick MD 20678	2	CS	CO	faucet in 211	250	FD	4/17/2018	7:00:00 PM	4/18/2018	6:52:00 AM	Chris Mlinaric	410-535-1800	4/22/2018	200.9	1	3.90	no	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Barstow Elementary	Calvert	P	04-028	5/17/2018	K20235	b78	1	Main Building	295 JW Williams Rd, Prince Fredrick MD 20678	2	CF	CO	bubbler in 210	250	FD	4/17/2018	7:00:00 PM	4/18/2018	6:40:00 AM	Chris Mlinaric	410-535-1800	4/22/2018	200.9	1	<1.0	no	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Barstow Elementary	Calvert	P	04-028	5/17/2018	K20236	79	1	Main Building	295 JW Williams Rd, Prince Fredrick MD 20678	2	CS	CO	faucet in 210	250	FD	4/17/2018	7:00:00 PM	4/18/2018	6:40:00 AM	Chris Mlinaric	410-535-1800	4/22/2018	200.9	1	1.00	no	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Barstow Elementary	Calvert	P	04-028	5/17/2018	K20237	80	1	Main Building	295 JW Williams Rd, Prince Fredrick MD 20678	2	CR	CO	faucet in grade 4 work room	250	FD	4/17/2018	7:00:00 PM	4/18/2018	6:55:00 AM	Chris Mlinaric	410-535-1800	4/22/2018	200.9	1	4.20	no	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Barstow Elementary	Calvert	P	04-028	5/17/2018	K20238	b81	1	Main Building	295 JW Williams Rd, Prince Fredrick MD 20678	2	CF	CO	bubbler in 205	250	FD	4/17/2018	7:00:00 PM	4/18/2018	6:34:00 AM	Lonnie Smith	410-535-1800	4/22/2018	200.9	1	<1.0	no	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Barstow Elementary	Calvert	P	04-028	5/17/2018	K20239	82	1	Main Building	295 JW Williams Rd, Prince Fredrick MD 20678	2	CS	CO	faucet in 205	250	FD	4/17/2018	7:00:00 PM	4/18/2018	6:34:00 AM	Lonnie Smith	410-535-1800	4/22/2018	200.9	1	2.60	no	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Barstow Elementary	Calvert	P	04-028	5/17/2018	K20240	b83	1	Main Building	295 JW Williams Rd, Prince Fredrick MD 20678	2	CF	CO	bubbler in 204	250	FD	4/17/2018	7:00:00 PM	4/18/2018	6:36:00 AM	Lonnie Smith	410-535-1800	4/22/2018	200.9	1	<1.0	no	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Barstow Elementary	Calvert	P	04-028	5/17/2018	K20241	84	1	Main Building	295 JW Williams Rd, Prince Fredrick MD 20678	2	CS	CO	faucet in 204	250	FD	4/17/2018	7:00:00 PM	4/18/2018	6:36:00 AM	Lonnie Smith	410-535-1800	4/22/2018	200.9	1	1.10	no	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Barstow Elementary	Calvert	P	04-028	5/17/2018	K20242	b85	1	Main Building	295 JW Williams Rd, Prince Fredrick MD 20678	2	CF	CO	bubbler in 203	250	FD	4/17/2018	7:00:00 PM	4/18/2018	6:37:00 AM	Lonnie Smith	410-535-1800	4/22/2018	200.9	1	<1.0	no	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Barstow Elementary	Calvert	P	04-028	5/17/2018	K20243	86	1	Main Building	295 JW Williams Rd, Prince Fredrick MD 20678	2	CS	CO	faucet in 203	250	FD	4/17/2018	7:00:00 PM	4/18/2018	6:37:00 AM	Lonnie Smith	410-535-1800	4/22/2018	200.9	1	3.10	no	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Barstow Elementary	Calvert	P	04-028	5/17/2018	K20244	b87	1	Main Building	295 JW Williams Rd, Prince Fredrick MD 20678	2	CF	CO	bubbler in 202	250	FD	4/17/2018	7:00:00 PM	4/18/2018	6:39:00 AM	Lonnie Smith	410-535-1800	4/22/2018	200.9	1	<1.0	no	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Barstow Elementary	Calvert	P	04-028	5/17/2018	K20245	88	1	Main Building	295 JW Williams Rd, Prince Fredrick MD 20678	2	CS	CO	faucet in 202	250	FD	4/17/2018	7:00:00 PM	4/18/2018	6:39:00 AM	Lonnie Smith	410-535-1800	4/22/2018	200.9	1	1.80	no	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Barstow Elementary	Calvert	P	04-028	5/17/2018	K20246	b89	1	Main Building	295 JW Williams Rd, Prince Fredrick MD 20678	2	CF	CO	bubbler in 201	250	FD	4/17/2018	7:00:00 PM	4/18/2018	6:41:00 AM	Lonnie Smith	410-535-1800	4/22/2018	200.9	1	<1.0	no	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Barstow Elementary	Calvert	P	04-028	5/17/2018	K20247	90	1	Main Building	295 JW Williams Rd, Prince Fredrick MD 20678	2	CS	CO	faucet in 201	250	FD	4/17/2018	7:00:00 PM	4/18/2018	6:41:00 AM	Lonnie Smith	410-535-1800	4/22/2018	200.9	1	1.40	no	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Barstow Elementary	Calvert	P	04-028	5/17/2018	K20248	91	1	Playground	295 JW Williams Rd, Prince Fredrick MD 20678	1	DF	CO	fountain on playground	250	FD	4/17/2018	7:00:00 PM	4/18/2018	6:46:00 AM	Lonnie Smith	410-535-1800	4/22/2018	200.9	1	<1.0	no	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Barstow Elementary	Calvert	P	04-028	5/17/2018	K20249	92	1	Main Building	295 JW Williams Rd, Prince Fredrick MD 20678	1	DF	CO	fountain outside of gym	250	FD	4/17/2018	7:00:00 PM	4/18/2018	6:49:00 AM	Lonnie Smith	410-535-1800	4/22/2018	200.9	1	<1.0	no	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Barstow Elementary	Calvert	P	04-028	5/17/2018	K20250	93	1	Main Building	295 JW Williams Rd, Prince Fredrick MD 20678	1	IM	CO	ice machine in lounge	250	FD	4/17/2018	7:00:00 PM	4/18/2018	6:04:00 AM	Chris Mlinaric	410-535-1800	4/22/2018	200.9	1	<1.0	no	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Barstow Elementary	Calvert	P	04-028	5/17/2018	K20251	94	1	Main Building	295 JW Williams Rd, Prince Fredrick MD 20678	1	IM	CO	ice machine in nurse room	250	FD	4/17/2018	7:00:00 PM	4/18/2018	5:52:00 AM	Chris Mlinaric	410-535-1800	4/22/2018	200.9	1	<1.0	no	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Barstow Elementary	Calvert	P	04-028	5/17/2018	K20252	95	1	Main Building	295 JW Williams Rd, Prince Fredrick MD 20678	1	CR	CO	faucet in band room storage	250	FD	4/17/2018	7:00:00 PM	4/18/2018	6:02:00 AM	Chris Mlinaric	410-535-1800	4/22/2018	200.9	1	<1.0	no	

Joy Ostroff Shields



Laboratory Manager