

Beach Elementary School

2018-2019 Testing Results

Laboratory Name	School Name	Laboratory Reporting Date	Floor #	School Outlet ID/Floor Plan ID	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Description/Location	Sample Type (Code)	Date Water Last Used	Time Water Last Used	Date Sample Collected	Time Sample Collected	Analysis Date	Lead Sample Result (ppb)	≥ 20.5 ppb AL?
Water Testing Laboratory of MD	Beach Elementary	2/23/2019	1	15*	CS	faucet in A-5	FD	2/5/2019	6:00:00 PM	2/6/2019	6:51:00 AM	2/14/2019	<1.0	No

Notes: Sample Site 15 faucet was replaced in February 2019

2017-2018 Testing Results

Laboratory Name	School Name	Laboratory Reporting Date	Floor #	School Outlet ID/Floor Plan ID	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Description/Location	Sample Type (Code)	Date Water Last Used	Time Water Last Used	Date Sample Collected	Time Sample Collected	Analysis Date	Lead Sample Result (ppb)	≥ 20.5 ppb AL?
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	1	DF	left fountain outside of cafeteria	FD	4/25/2018	8:00:00 PM	4/26/2018	6:01:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	2	DF	right fountain outside of cafeteria	FD	4/25/2018	8:00:00 PM	4/26/2018	6:01:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	3	DF	fountain outside of gym	FD	4/25/2018	8:00:00 PM	4/26/2018	6:17:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	4	TL	faucet in lounge	FD	4/25/2018	8:00:00 PM	4/26/2018	5:59:00 AM	5/2/2018	<1.0	no

Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	5	KS	left faucet 2 compartment sink	FD	4/25/2018	8:00:00 PM	4/26/2018	6:02:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	6	KS	left faucet 3 compartment sink	FD	4/25/2018	8:00:00 PM	4/26/2018	6:02:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	7	KS	right faucet 3 compartment sink	FD	4/25/2018	8:00:00 PM	4/26/2018	6:03:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	b8	CF	bubbler in A-1	FD	4/25/2018	8:00:00 PM	4/26/2018	6:07:00 AM	5/3/2018	34.60	yes
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	9	CS	faucet in A-1	FD	4/25/2018	8:00:00 PM	4/26/2018	6:07:00 AM	5/3/2018	3.90	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	b10	CF	bubbler in A-3	FD	4/25/2018	8:00:00 PM	4/26/2018	6:10:00 AM	5/3/2018	<1.0	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	11	CS	faucet in A-3	FD	4/25/2018	8:00:00 PM	4/26/2018	6:10:00 AM	5/3/2018	3.00	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	b12	CF	bubbler in A-4	FD	4/25/2018	8:00:00 PM	4/26/2018	6:11:00 AM	5/3/2018	<1.0	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	13	CS	faucet in A-4	FD	4/25/2018	8:00:00 PM	4/26/2018	6:11:00 AM	5/3/2018	2.10	no
Water Testing	Beach Elementary	6/2/2018	1	b14	CF	bubbler in A-5	FD	4/25/2018	8:00:00 PM	4/26/2018	6:16:00 AM	5/3/2018	1.30	no

Laboratory of MD														
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	15	CS	faucet in A-5	FD	4/25/2018	8:00:00 PM	4/26/2018	6:16:00 AM	5/3/2018	7.60	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	b16	CF	bubbler in KDG1	FD	4/25/2018	8:00:00 PM	4/26/2018	6:14:00 AM	5/3/2018	<1.0	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	17	CS	faucet in KDG1	FD	4/25/2018	8:00:00 PM	4/26/2018	6:14:00 AM	5/3/2018	1.90	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	18	CR	left faucet in art	FD	4/25/2018	8:00:00 PM	4/26/2018	6:17:00 AM	5/3/2018	1.00	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	19	CR	right faucet in art	FD	4/25/2018	8:00:00 PM	4/26/2018	6:17:00 AM	5/3/2018	1.60	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	b20	CF	bubbler in KDG2	FD	4/25/2018	8:00:00 PM	4/26/2018	6:19:00 AM	5/3/2018	<1.0	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	21	CS	faucet in KDG2	FD	4/25/2018	8:00:00 PM	4/26/2018	6:19:00 AM	5/3/2018	<1.0	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	b22	CF	bubbler in KDG3	FD	4/25/2018	8:00:00 PM	4/26/2018	6:21:00 AM	5/3/2018	<1.0	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	23	CS	faucet in KDG3	FD	4/25/2018	8:00:00 PM	4/26/2018	6:21:00 AM	5/3/2018	<1.0	no

Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	b24	CF	bubbler in KDG4	FD	4/25/2018	8:00:00 PM	4/26/2018	6:23:00 AM	5/3/2018	<1.0	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	25	CS	faucet in KDG4	FD	4/25/2018	8:00:00 PM	4/26/2018	6:23:00 AM	5/3/2018	<1.0	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	b26	CF	bubbler in C-6	FD	4/25/2018	8:00:00 PM	4/26/2018	6:18:00 AM	5/3/2018	1.50	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	27	CS	faucet in C-6	FD	4/25/2018	8:00:00 PM	4/26/2018	6:18:00 AM	5/3/2018	2.10	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	b28	CF	bubbler in C-4	FD	4/25/2018	8:00:00 PM	4/26/2018	6:19:00 AM	5/3/2018	<1.0	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	29	CS	faucet in C-4	FD	4/25/2018	8:00:00 PM	4/26/2018	6:19:00 AM	5/3/2018	1.80	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	b30	CF	bubbler in C-5	FD	4/25/2018	8:00:00 PM	4/26/2018	6:22:00 AM	5/3/2018	<1.0	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	31	CS	faucet in C-5	FD	4/25/2018	8:00:00 PM	4/26/2018	6:22:00 AM	5/3/2018	1.40	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	b32	CF	bubbler in C-3	FD	4/25/2018	8:00:00 PM	4/26/2018	6:23:00 AM	5/3/2018	<1.0	no
Water Testing	Beach Elementary	6/2/2018	1	33	CS	faucet in C-3	FD	4/25/2018	8:00:00 PM	4/26/2018	6:23:00 AM	5/3/2018	<1.0	no

Laboratory of MD														
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	b34	CF	bubbler in C-2	FD	4/25/2018	8:00:00 PM	4/26/2018	6:25:00 AM	5/3/2018	1.10	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	35	CS	faucet in C-2	FD	4/25/2018	8:00:00 PM	4/26/2018	6:25:00 AM	5/3/2018	<1.0	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	b36	CF	bubbler in C-1	FD	4/25/2018	8:00:00 PM	4/26/2018	6:26:00 AM	5/3/2018	1.00	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	37	CR	faucet in C-1	FD	4/25/2018	8:00:00 PM	4/26/2018	6:26:00 AM	5/3/2018	3.90	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	38	CR	faucet in Pre-k	FD	4/25/2018	8:00:00 PM	4/26/2018	6:12:00 AM	5/3/2018	<1.0	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	39	CR	faucet in media center work room	FD	4/25/2018	8:00:00 PM	4/26/2018	6:10:00 AM	5/3/2018	1.10	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	b40	CF	left bubbler across b-13	FD	4/25/2018	8:00:00 PM	4/26/2018	6:08:00 AM	5/3/2018	<1.0	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	41	CS	left faucet across b-13	FD	4/25/2018	8:00:00 PM	4/26/2018	6:08:00 AM	5/3/2018	<1.0	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	b42	CF	middle bubbler across b-13	FD	4/25/2018	8:00:00 PM	4/26/2018	6:07:00 AM	5/3/2018	<1.0	no

Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	43	CS	middle faucet across b-13	FD	4/25/2018	8:00:00 PM	4/26/2018	6:07:00 AM	5/3/2018	3.00	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	b44	CF	right bubbler across b-13	FD	4/25/2018	8:00:00 PM	4/26/2018	6:09:00 AM	5/3/2018	<1.0	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	45	CS	middle bubbler across b-13	FD	4/25/2018	8:00:00 PM	4/26/2018	6:09:00 AM	5/3/2018	<1.0	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	b46	CF	left bubbler across b-14	FD	4/25/2018	8:00:00 PM	4/26/2018	6:05:00 AM	5/3/2018	<1.0	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	47	CS	left faucet across b-14	FD	4/25/2018	8:00:00 PM	4/26/2018	6:05:00 AM	5/3/2018	2.40	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	b48	CF	middle bubbler across b-14	FD	4/25/2018	8:00:00 PM	4/26/2018	6:04:00 AM	5/3/2018	<1.0	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	49	CS	middle faucet across b-14	FD	4/25/2018	8:00:00 PM	4/26/2018	6:04:00 AM	5/3/2018	<1.0	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	b50	CF	right bubbler across b-14	FD	4/25/2018	8:00:00 PM	4/26/2018	6:03:00 AM	5/3/2018	<1.0	no
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	51	CS	right faucet across b-14	FD	4/25/2018	8:00:00 PM	4/26/2018	6:03:00 AM	5/3/2018	<1.0	no
Water Testing	Beach Elementary	6/2/2018	1	52	NO	faucet in health room	FD	4/25/2018	8:00:00 PM	4/26/2018	6:30:00 AM	5/3/2018	<1.0	no

Laboratory of MD														
Water Testing Laboratory of MD	Beach Elementary	6/2/2018	1	53	IM	ice machine in kitchen	FD	4/25/2018	8:00:00 PM	4/26/2018	6:04:00 AM	5/3/2018	<1.0	no