

Career & Technology Academy

2018-2019 Testing Results

Laboratory Name	School Name	Laboratory Reporting Date	Floor #	School Outlet ID/Floor Plan ID	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Description/Location	Sample Type (Code)	Date Water Last Used	Time Water Last Used	Date Sample Collected	Time Sample Collected	Analysis Date	Lead Sample Result (ppb)	≥ 20.5 ppb AL?
Water Testing Laboratory of MD	Career and Technology Academy	2/23/2019	1	13*	CR	right faucet by culinary arts walk in freezer	FD	2/5/2019	4:20:00 PM	2/6/2019	5:50:00 AM	2/14/2019	1.8	No
Water Testing Laboratory of MD	Career and Technology Academy	2/23/2019	1	34**	HE	faucet in exam room #6	FD	2/5/2019	4:20:00 PM	2/6/2019	5:50:00 AM	2/14/2019	<1.0	No

Notes: Sample Sites 13 and 34 faucets were replaced in February 2019

2017-2018 Testing Results

Laboratory Name	School Name	Laboratory Reporting Date	Floor #	School Outlet ID/Floor Plan ID	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Description/Location	Sample Type (Code)	Date Water Last Used	Time Water Last Used	Date Sample Collected	Time Sample Collected	Analysis Date	Lead Sample Result (ppb)	≥ 20.5 ppb AL?
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		1	DF	water fountain outside culinary arts	FD	4/17/2018	5:00:00 PM	4/18/2018	5:02:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		2	DF	water fountain by cosmetology	FD	4/17/2018	5:00:00 PM	4/18/2018	5:05:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		3	DF	left fountain in home improvements	FD	4/17/2018	5:00:00 PM	4/18/2018	5:07:00 AM	4/22/2018	1.00	no

Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		4	DF	right fountain in home improvements	FD	4/17/2018	5:00:00 PM	4/18/2018	5:08:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		5	DF	water fountain In plumbing lab	FD	4/17/2018	5:00:00 PM	4/18/2018	5:14:00 AM	4/22/2018	1.50	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		6	DF	water fountain In electric lab	FD	4/17/2018	5:00:00 PM	4/18/2018	5:15:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		7	DF	water fountain Across from electronics lab	FD	4/17/2018	5:00:00 PM	4/18/2018	5:18:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		8	DF	water fountain welding shop	FD	4/17/2018	5:00:00 PM	4/18/2018	5:10:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		9	DF	water fountain In automotive	FD	4/17/2018	5:00:00 PM	4/18/2018	5:11:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		10	TL	faucet in staff lounge	FD	4/17/2018	5:00:00 PM	4/18/2018	5:02:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		11	HE	faucet in food prep classroom	FD	4/17/2018	5:00:00 PM	4/18/2018	5:04:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		12	HE	left faucet by culinary arts walk in freezer	FD	4/17/2018	5:00:00 PM	4/18/2018	5:05:00 AM	4/22/2018	3.20	no
Water Testing	Career and Technology Academy	6/1/2018		13*	HE	right faucet by culinary arts walk in freezer	FD	4/17/2018	5:00:00 PM	4/18/2018	5:06:00 AM	4/22/2018	5.30	no

Laboratory of MD														
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		14	HE	faucet in advanced cooking	FD	4/17/2018	5:00:00 PM	4/18/2018	5:08:00 AM	4/22/2018	2.10	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		15	HE	left faucet across from dishwasher	FD	4/17/2018	5:00:00 PM	4/18/2018	5:07:00 AM	4/22/2018	1.40	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		16	HE	right faucet across from dishwasher	FD	4/17/2018	5:00:00 PM	4/18/2018	5:07:00 AM	4/22/2018	1.30	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		17	CR	faucet next to cosmetology dispensary	FD	4/17/2018	5:00:00 PM	4/18/2018	5:11:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		18	CR	faucet next to eye wash station	FD	4/17/2018	5:00:00 PM	4/18/2018	5:12:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		19	CR	faucet next to cosmetology planning	FD	4/17/2018	5:00:00 PM	4/18/2018	5:13:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		20	CR	faucet in manicure/pedicure area	FD	4/17/2018	5:00:00 PM	4/18/2018	5:14:00 AM	4/22/2018	1.00	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		21	CR	faucet in networking , Cool Beans coffee	FD	4/17/2018	5:00:00 PM	4/18/2018	5:16:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		22	CR	faucet in precision machining	FD	4/17/2018	5:00:00 PM	4/18/2018	5:17:00 AM	4/22/2018	<1.0	no

Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		23	CR	faucet in first aid	FD	4/17/2018	5:00:00 PM	4/18/2018	5:19:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		24	TL	faucet in mail room	FD	4/17/2018	5:00:00 PM	4/18/2018	5:20:00 AM	4/22/2018	2.20	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		25	CR	faucet in electronics lab	FD	4/17/2018	5:00:00 PM	4/18/2018	5:22:00 AM	4/22/2018	1.80	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		26	CR	faucet in engineering lab	FD	4/17/2018	5:00:00 PM	4/18/2018	5:23:00 AM	4/22/2018	1.70	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		27	CR	left faucet in pre-nursing lab	FD	4/17/2018	5:00:00 PM	4/18/2018	5:20:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		28	CR	middle faucet Pre-nursing lab	FD	4/17/2018	5:00:00 PM	4/18/2018	5:23:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		29	CR	right faucet pre-nursing lab	FD	4/17/2018	5:00:00 PM	4/18/2018	5:24:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		30	CR	faucet in exam room #1	FD	4/17/2018	5:00:00 PM	4/18/2018	5:26:00 AM	4/22/2018	2.50	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		31	CR	faucet in exam room #3	FD	4/17/2018	5:00:00 PM	4/18/2018	5:27:00 AM	4/22/2018	<1.0	no
Water Testing	Career and Technology Academy	6/1/2018		32	CR	faucet in exam room #4	FD	4/17/2018	5:00:00 PM	4/18/2018	5:28:00 AM	4/22/2018	1.60	no

Laboratory of MD														
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		33	CR	faucet in exam room #5	FD	4/17/2018	5:00:00 PM	4/18/2018	5:28:00 AM	4/22/2018	3.20	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		34**	CR	faucet in exam room #6	FD	4/17/2018	5:00:00 PM	4/18/2018	5:27:00 AM	4/22/2018	5.30	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		35	CR	left faucet medical asst. lab	FD	4/17/2018	5:00:00 PM	4/18/2018	5:26:00 AM	4/22/2018	1.00	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		36	CR	right faucet medical asst. lab	FD	4/17/2018	5:00:00 PM	4/18/2018	5:26:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		37	CR	faucet in medical asst. lab	FD	4/17/2018	5:00:00 PM	4/18/2018	5:26:00 AM	4/22/2018	2.00	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		38	CR	faucet in CAD lab	FD	4/17/2018	5:00:00 PM	4/18/2018	5:24:00 AM	4/22/2018	1.40	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		39	IM	ice machine in culinary arts	FD	4/17/2018	5:00:00 PM	4/18/2018	5:08:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		1	DF	water fountain outside culinary arts	FD	4/17/2018	5:00:00 PM	4/18/2018	5:02:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		2	DF	water fountain by cosmetology	FD	4/17/2018	5:00:00 PM	4/18/2018	5:05:00 AM	4/22/2018	<1.0	no

Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		3	DF	left fountain in home improvements	FD	4/17/2018	5:00:00 PM	4/18/2018	5:07:00 AM	4/22/2018	1.00	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		4	DF	right fountain in home improvements	FD	4/17/2018	5:00:00 PM	4/18/2018	5:08:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		5	DF	water fountain In plumbing lab	FD	4/17/2018	5:00:00 PM	4/18/2018	5:14:00 AM	4/22/2018	1.50	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		6	DF	water fountain In electric lab	FD	4/17/2018	5:00:00 PM	4/18/2018	5:15:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		7	DF	water fountain Across from electronics lab	FD	4/17/2018	5:00:00 PM	4/18/2018	5:18:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		8	DF	water fountain welding shop	FD	4/17/2018	5:00:00 PM	4/18/2018	5:10:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		9	DF	water fountain In automotive	FD	4/17/2018	5:00:00 PM	4/18/2018	5:11:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		10	TL	faucet in staff lounge	FD	4/17/2018	5:00:00 PM	4/18/2018	5:02:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		11	HE	faucet in food prep classroom	FD	4/17/2018	5:00:00 PM	4/18/2018	5:04:00 AM	4/22/2018	<1.0	no
Water Testing	Career and Technology Academy	6/1/2018		12	HE	left faucet by culinary arts walk in freezer	FD	4/17/2018	5:00:00 PM	4/18/2018	5:05:00 AM	4/22/2018	3.20	no

Laboratory of MD														
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		13*	HE	right faucet by culinary arts walk in freezer	FD	4/17/2018	5:00:00 PM	4/18/2018	5:06:00 AM	4/22/2018	5.30	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		14	HE	faucet in advanced cooking	FD	4/17/2018	5:00:00 PM	4/18/2018	5:08:00 AM	4/22/2018	2.10	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		15	HE	left faucet across from dishwasher	FD	4/17/2018	5:00:00 PM	4/18/2018	5:07:00 AM	4/22/2018	1.40	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		16	HE	right faucet across from dishwasher	FD	4/17/2018	5:00:00 PM	4/18/2018	5:07:00 AM	4/22/2018	1.30	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		17	CR	faucet next to cosmetology dispensary	FD	4/17/2018	5:00:00 PM	4/18/2018	5:11:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		18	CR	faucet next to eye wash station	FD	4/17/2018	5:00:00 PM	4/18/2018	5:12:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		19	CR	faucet next to cosmetology planning	FD	4/17/2018	5:00:00 PM	4/18/2018	5:13:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		20	CR	faucet in manicure/pedicure area	FD	4/17/2018	5:00:00 PM	4/18/2018	5:14:00 AM	4/22/2018	1.00	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		21	CR	faucet in networking , Cool Beans coffee	FD	4/17/2018	5:00:00 PM	4/18/2018	5:16:00 AM	4/22/2018	<1.0	no

Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		22	CR	faucet in precision machining	FD	4/17/2018	5:00:00 PM	4/18/2018	5:17:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		23	CR	faucet in first aid	FD	4/17/2018	5:00:00 PM	4/18/2018	5:19:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		24	TL	faucet in mail room	FD	4/17/2018	5:00:00 PM	4/18/2018	5:20:00 AM	4/22/2018	2.20	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		25	CR	faucet in electronics lab	FD	4/17/2018	5:00:00 PM	4/18/2018	5:22:00 AM	4/22/2018	1.80	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		26	CR	faucet in engineering lab	FD	4/17/2018	5:00:00 PM	4/18/2018	5:23:00 AM	4/22/2018	1.70	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		27	CR	left faucet in pre-nursing lab	FD	4/17/2018	5:00:00 PM	4/18/2018	5:20:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		28	CR	middle faucet Pre-nursing lab	FD	4/17/2018	5:00:00 PM	4/18/2018	5:23:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		29	CR	right faucet pre-nursing lab	FD	4/17/2018	5:00:00 PM	4/18/2018	5:24:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		30	CR	faucet in exam room #1	FD	4/17/2018	5:00:00 PM	4/18/2018	5:26:00 AM	4/22/2018	2.50	no
Water Testing	Career and Technology Academy	6/1/2018		31	CR	faucet in exam room #3	FD	4/17/2018	5:00:00 PM	4/18/2018	5:27:00 AM	4/22/2018	<1.0	no

Laboratory of MD														
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		32	CR	faucet in exam room #4	FD	4/17/2018	5:00:00 PM	4/18/2018	5:28:00 AM	4/22/2018	1.60	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		33	CR	faucet in exam room #5	FD	4/17/2018	5:00:00 PM	4/18/2018	5:28:00 AM	4/22/2018	3.20	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		34**	CR	faucet in exam room #6	FD	4/17/2018	5:00:00 PM	4/18/2018	5:27:00 AM	4/22/2018	5.30	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		35	CR	left faucet medical asst. lab	FD	4/17/2018	5:00:00 PM	4/18/2018	5:26:00 AM	4/22/2018	1.00	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		36	CR	right faucet medical asst. lab	FD	4/17/2018	5:00:00 PM	4/18/2018	5:26:00 AM	4/22/2018	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		37	CR	faucet in medical asst. lab	FD	4/17/2018	5:00:00 PM	4/18/2018	5:26:00 AM	4/22/2018	2.00	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		38	CR	faucet in CAD lab	FD	4/17/2018	5:00:00 PM	4/18/2018	5:24:00 AM	4/22/2018	1.40	no
Water Testing Laboratory of MD	Career and Technology Academy	6/1/2018		39	IM	ice machine in culinary arts	FD	4/17/2018	5:00:00 PM	4/18/2018	5:08:00 AM	4/22/2018	<1.0	no