

Laboratory Certification ID	Laboratory Name	City/State	Laboratory Certification ID (Laboratory Performing Sample Analysis)	School Name	County	School Type (Code)	School ID	Laboratory Reporting Date	Laboratory Sample ID	School Outlet ID/Floor Plan ID	Building #	Building Name	Building Address	Floor #	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Use (code)	Sample Tap/Outlet Description/Location	Sample Volume (mL)	Sample Type (Code)	Date Water Last Used	Time Water Last Used	Date Sample Collected	Time Sample Collected	Sampler Name	Sampler Telephone number	Analysis Date	Analysis Method	Detection Limit (ppb)	Lead Sample Result (ppb)	≥ 20.5 ppb AL?	Notes
							09- - - - -																								
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20833	1	1 Main Building	11655 H G Trueman Road Lusby, MD	1	DF	CO	fountain outside of 28 & 29	250	FD	4/30/2018	8:15:00 PM	5/1/2018	6:38:00 AM	Lonnie Smith	410-535-1800	5/8/2018	200.9	1	<1.0	No		
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20834	2	1 Main Building	11655 H G Trueman Road Lusby, MD	1	DF	CO	fountain outside of cafeteria	250	FD	4/30/2018	8:15:00 PM	5/1/2018	6:30:00 AM	Lonnie Smith	410-535-1800	5/8/2018	200.9	1	1.1	No		
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20835	3	1 Main Building	11655 H G Trueman Road Lusby, MD	1	DF	CO	fountain in cafeteria	250	FD	4/30/2018	8:15:00 PM	5/1/2018	6:29:00 AM	Lonnie Smith	410-535-1800	5/8/2018	200.9	1	<1.0	No		
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20836	4	1 Main Building	11655 H G Trueman Road Lusby, MD	1	DF	CO	fountain in gym	250	FD	4/30/2018	8:15:00 PM	5/1/2018	6:51:00 AM	Lonnie Smith	410-535-1800	5/8/2018	200.9	1	<1.0	No		
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20837	5	1 Main Building	11655 H G Trueman Road Lusby, MD	1	DF	CO	fountain in room 18 & 19	250	FD	4/30/2018	8:15:00 PM	5/1/2018	7:02:00 AM	Lonnie Smith	410-535-1800	5/8/2018	200.9	1	<1.0	No		
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20838	6	1 Main Building	11655 H G Trueman Road Lusby, MD	1	DF	CO	fountain in room 15, 16 & 17	250	FD	4/30/2018	8:15:00 PM	5/1/2018	7:03:00 AM	Chris Mlinaric	410-535-1800	5/8/2018	200.9	1	<1.0	No		
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20839	7	1 Main Building	11655 H G Trueman Road Lusby, MD	1	DF	CO	fountain in room 12, 13 & 14	250	FD	4/30/2018	8:15:00 PM	5/1/2018	6:59:00 AM	Chris Mlinaric	410-535-1800	5/8/2018	200.9	1	<1.0	No		
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20840	8	1 Main Building	11655 H G Trueman Road Lusby, MD	1	DF	CO	fountain in room 10 & 11	250	FD	4/30/2018	8:15:00 PM	5/1/2018	6:52:00 AM	Chris Mlinaric	410-535-1800	5/8/2018	200.9	1	<1.0	No		
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20841	9	1 Main Building	11655 H G Trueman Road Lusby, MD	1	NO	CO	faucet in health room	250	FD	4/30/2018	8:15:00 PM	5/1/2018	6:31:00 AM	Lonnie Smith	410-535-1800	5/8/2018	200.9	1	<1.0	No		
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20842	b10	1 Main Building	11655 H G Trueman Road Lusby, MD	1	TL	CO	bubbler in lounge	250	FD	4/30/2018	8:15:00 PM	5/1/2018	6:34:00 AM	Lonnie Smith	410-535-1800	5/8/2018	200.9	1	6.7	No		
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20843	11	1 Main Building	11655 H G Trueman Road Lusby, MD	1	CF	CO	faucet in lounge	250	FD	4/30/2018	8:15:00 PM	5/1/2018	6:34:00 AM	Lonnie Smith	410-535-1800	5/8/2018	200.9	1	1.1	No		
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20844	b12	1 Main Building	11655 H G Trueman Road Lusby, MD	1	CF	CO	bubbler in 29	250	FD	5/2/2018	9:50:00 AM	5/2/2018	6:00:00 PM	Chris Mlinaric	410-535-1800	5/8/2018	200.9	1	2.7	No		
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20845	13	1 Main Building	11655 H G Trueman Road Lusby, MD	1	CS	CO	faucet in 29	250	FD	4/30/2018	8:15:00 PM	5/1/2018	6:37:00 AM	Lonnie Smith	410-535-1800	5/8/2018	200.9	1	2.8	No		
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20846	b14	1 Main Building	11655 H G Trueman Road Lusby, MD	1	CF	CO	bubbler in 28	250	FD	4/30/2018	8:15:00 PM	5/1/2018	6:39:00 AM	Lonnie Smith	410-535-1800	5/8/2018	200.9	1	1.3	No		
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20847	15	1 Main Building	11655 H G Trueman Road Lusby, MD	1	CS	CO	faucet in 28	250	FD	4/30/2018	8:15:00 PM	5/1/2018	6:39:00 AM	Lonnie Smith	410-535-1800	5/8/2018	200.9	1	3.6	No		
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20848	b16	1 Main Building	11655 H G Trueman Road Lusby, MD	1	CF	CO	bubbler in 27	250	FD	4/30/2018	8:15:00 PM	5/1/2018	6:43:00 AM	Lonnie Smith	410-535-1800	5/8/2018	200.9	1	3.0	No		
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20849	17	1 Main Building	11655 H G Trueman Road Lusby, MD	1	CS	CO	faucet in 27	250	FD	4/30/2018	8:15:00 PM	5/1/2018	6:43:00 AM	Lonnie Smith	410-535-1800	5/8/2018	200.9	1	4.4	No		
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20850	b18	1 Main Building	11655 H G Trueman Road Lusby, MD	1	CF	CO	bubbler in 26	250	FD	4/30/2018	8:15:00 PM	5/1/2018	6:45:00 AM	Lonnie Smith	410-535-1800	5/8/2018	200.9	1	6.7	No		
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20851	19	1 Main Building	11655 H G Trueman Road Lusby, MD	1	CS	CO	faucet in 26	250	FD	4/30/2018	8:15:00 PM	5/1/2018	6:45:00 AM	Lonnie Smith	410-535-1800	5/8/2018	200.9	1	5.4	No		
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20852	b20	1 Main Building	11655 H G Trueman Road Lusby, MD	1	CF	CO	bubbler in 30	250	FD	4/30/2018	8:15:00 PM	5/1/2018	6:48:00 AM	Lonnie Smith	410-535-1800	5/8/2018	200.9	1	1.8	No		
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20853	21	1 Main Building	11655 H G Trueman Road Lusby, MD	1	CR	CO	faucet in 30	250	FD	4/30/2018	8:15:00 PM	5/1/2018	6:48:00 AM	Lonnie Smith	410-535-1800	5/8/2018	200.9	1	2.0	No		
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20854	22	1 Main Building	11655 H G Trueman Road Lusby, MD	1	CR	CO	solo faucet in 30	250	FD	4/30/2018	8:15:00 PM	5/1/2018	6:49:00 AM	Lonnie Smith	410-535-1800	5/8/2018	200.9	1	2.0	No		
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20855	23	1 Main Building	11655 H G Trueman Road Lusby, MD	1	KS	CO	left faucet in kitchen	250	FD	4/30/2018	8:15:00 PM	5/1/2018	6:27:00 AM	Lonnie Smith	410-535-1800	5/8/2018	200.9	1	2.8	No		
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20856	24	1 Main Building	11655 H G Trueman Road Lusby, MD	1	KS	CO	right faucet in kitchen	250	FD	4/30/2018	8:15:00 PM	5/1/2018	6:27:00 AM	Lonnie Smith	410-535-1800	5/8/2018	200.9	1	4.4	No		
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20857	25	1 Main Building	11655 H G Trueman Road Lusby, MD	1	KS	CO	solo faucet in two compartment sink	250	FD	4/30/2018	8:15:00 PM	5/1/2018	6:27:00 AM	Lonnie Smith	410-535-1800	5/8/2018	200.9	1	5.5	No		
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20858	27	1 Main Building	11655 H G Trueman Road Lusby, MD	1	CS	CO	left faucet in media center	250	FD	4/30/2018	8:15:00 PM	5/1/2018	6:55:00 AM	Lonnie Smith	410-535-1800	5/8/2018	200.9	1	4.3	No		
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20859	29	1 Main Building	11655 H G Trueman Road Lusby, MD	1	CS	CO	faucet by media center	250	FD	4/30/2018	8:15:00 PM	5/1/2018	6:53:00 AM	Lonnie Smith	410-535-1800	5/8/2018	200.9	1	8.8	No		
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20860	b30	1 Main Building	11655 H G Trueman Road Lusby, MD	1	CF	CO	left bubbler outside of 27	250	FD	4/30/2018	8:15:00 PM	5/1/2018	6:57:00 AM	Lonnie Smith	410-535-1800	5/8/2018	200.9	1	1.2	No		
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20861	31	1 Main Building	11655 H G Trueman Road Lusby, MD	1	CS	CO	left faucet outside of 27	250	FD	4/30/2018	8:15:00 PM	5/1/2018	6:57:00 AM	Lonnie Smith	410-535-1800	5/8/2018	200.9	1	<1.0	No		
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20862	b32	1 Main Building	11655 H G Trueman Road Lusby, MD	1	CF	CO	middle bubbler outside of 27	250	FD	4/30/2018	8:15:00 PM	5/1/2018	6:59:00 AM	Lonnie Smith	410-535-1800	5/8/2018	200.9	1	1.4	No		
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20863	33	1 Main Building	11655 H G Trueman Road Lusby, MD	1	CS	CO	middle faucet outside of 27	250	FD	4/30/2018	8:15:00 PM	5/1/2018	6:59:00 AM	Lonnie Smith	410-535-1800	5/8/2018	200.9	1	1.2	No		

Laboratory Certification ID	Laboratory Name	City/State	Laboratory Certification ID (Laboratory Performing Sample Analysis)	School Name	County	School Type (Code)	School ID	Laboratory Reporting Date	Laboratory Sample ID	School Outlet ID/Floor Plan ID	Building #	Building Name	Building Address	Floor #	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Use (code)	Sample Tap/Outlet Description/Location	Sample Volume (mL)	Sample Type (Code)	Date Water Last Used	Time Water Last Used	Date Sample Collected	Time Sample Collected	Sampler Name	Sampler Telephone number	Analysis Date	Analysis Method	Detection Limit (ppb)	Lead Sample Result (ppb)	≥ 20.5 ppb AL?	Notes
							09- - - - -																								
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20895	67	1	Main Building	11655 H G Trueman Road Lusby, MD	1	CS	CO	faucet in 21	250	FD	4/30/2018	8:15:00 PM	5/1/2018	6:50:00 AM	Chris Mlinaric	410-535-1800	5/9/2018	200.9	1	<1.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20896	69	1	Main Building	11655 H G Trueman Road Lusby, MD	1	CS	CO	faucet in 7	250	FD	4/30/2018	8:15:00 PM	5/1/2018	6:49:00 AM	Chris Mlinaric	410-535-1800	5/9/2018	200.9	1	3.1	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20897	71	1	Main Building	11655 H G Trueman Road Lusby, MD	1	CS	CO	faucet in 2	250	FD	4/30/2018	8:15:00 PM	5/1/2018	6:31:00 AM	Chris Mlinaric	410-535-1800	5/9/2018	200.9	1	3.7	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20898	73	1	Main Building	11655 H G Trueman Road Lusby, MD	1	DF	CO	fountain on playground	250	FD	4/30/2018	8:15:00 PM	5/1/2018	7:08:00 AM	Lonnie Smith	410-535-1800	5/9/2018	200.9	1	<1.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Appeal Elementary	Calvert	P	04.013	7/21/2018	K20899	75	1	Main Building	11655 H G Trueman Road Lusby, MD	1	IM	CO	ice machine in nurse office	250	FD	4/30/2018	8:15:00 PM	5/1/2018	6:32:00 AM	Lonnie Smith	410-535-1800	5/9/2018	200.9	1	<1.0	No	

I do hereby affirm that this record contains no willfull misrepresentations or falsifications and that this information given by me is true and complete to the best of my knowledge.

Joy Ostroff Shields



Laboratory Manager