

# Patuxent High School

## 2018-2019 Testing Results

Laboratory Name	School Name	Laboratory Reporting Date	Floor #	School Outlet ID/Floor Plan ID	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Description/Location	Sample Type (Code)	Date and Time Water Last Used	Date and Time Sample Collected	Analysis Date	Lead Sample Result (ppb)	≥ 20.5 ppb AL?
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	1	DF	Bottle Filler in Lobby	FD	4/24/2019 8:00PM	4/25/19 4:36AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	1	2	DF	Fountain in Adult Ed Trailer	FD	4/24/2019 8:00PM	4/25/19 5:55AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	3	DF	left fountain outside 208	FD	4/24/2019 8:00PM	4/25/19 4:37AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	4	DF	right fountain outside 208	FD	4/24/2019 8:00PM	4/25/19 4:38AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	5	DF	left fountain outside 265	FD	4/24/2019 8:00PM	4/25/19 5:07AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	6	DF	right fountain outside 265	FD	4/24/2019 8:00PM	4/25/19 5:07AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	7	DF	left fountain outside 272	FD	4/24/2019 8:00PM	4/25/19 5:08 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	8	DF	right fountain outside 272	FD	4/24/2019 8:00PM	4/25/19 5:08 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	9	DF	left fountain outside 288	FD	4/24/2019 8:00PM	4/25/19 5:14 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	10	DF	right fountain outside 288	FD	4/24/2019 8:00PM	4/25/19 5:14 AM	4/29/2019	0	No

Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	11	DF	left fountain outside 292	FD	4/24/2019 8:00PM	4/25/19 5:16 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	12	DF	right fountain outside 292	FD	4/24/2019 8:00PM	4/25/19 5:16 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	13	DF	left fountain outside G05	FD	4/24/2019 8:00PM	4/25/19 5:23 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	14	DF	right fountain outside G05	FD	4/24/2019 8:00PM	4/25/19 5:23 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	3	15	DF	left fountain outside 330	FD	4/24/2019 8:00PM	4/25/19 5:05 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	3	16	DF	right fountain outside 330	FD	4/24/2019 8:00PM	4/25/19 5:05 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	3	17	DF	left fountain outside 322	FD	4/24/2019 8:00PM	4/25/19 5:07 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	3	18	DF	right fountain outside 322	FD	4/24/2019 8:00PM	4/25/19 5:07 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	3	19	DF	left fountain outside 344	FD	4/24/2019 8:00PM	4/25/19 5:02 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	3	20	DF	right fountain outside 344	FD	4/24/2019 8:00PM	4/25/19 5:02 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	3	21	DF	left fountain outside 355	FD	4/24/2019 8:00PM	4/25/19 5:01 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	3	22	DF	right fountain outside 355	FD	4/24/2019 8:00PM	4/25/19 5:01 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	3	23	DF	left fountain outside 315	FD	4/24/2019 8:00PM	4/25/19 5:03 AM	4/29/2019	0	No

Water Testing Laboratory of MD	Patuxent High School	6/10/2019	3	24	DF	right fountain outside 315	FD	4/24/2019 8:00PM	4/25/19 5:03 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	1	25	DF	left fountain outside 116	FD	4/24/2019 8:00PM	4/25/19 4:47 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	1	26	DF	right fountain outside 116	FD	4/24/2019 8:00PM	4/25/19 4:47 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	1	27	DF	fountain outside 105	FD	4/24/2019 8:00PM	4/25/19 4:41 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	1	28	DF	left fountain outside 142	FD	4/24/2019 8:00PM	4/25/19 4:52 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	1	29	DF	right fountain outside 141	FD	4/24/2019 8:00PM	4/25/19 4:52 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	1	30	DF	left fountain outside 133	FD	4/24/2019 8:00PM	4/25/19 4:53 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	1	31	DF	right fountain outside 133	FD	4/24/2019 8:00PM	4/25/19 4:53 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	32	DF	Left fountain in 216	FD	4/24/2019 8:00PM	4/25/19 4:54 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	33	DF	right fountain in 216	FD	4/24/2019 8:00PM	4/25/19 4:54 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	34	CR	faucet in 207	FD	4/24/2019 8:00PM	4/25/19 4:39 AM	4/29/2019	11.6	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	35	KS	faucet in concession stand	FD	4/24/2019 8:00PM	4/25/19 5:27 AM	4/29/2019	1.7	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	36	KS	dish washer sprayer	FD	4/24/2019 8:00PM	4/25/19 4:42 AM	4/29/2019	0	No

Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	37	KS	sprayer by handwash sink	FD	4/24/2019 8:00PM	4/25/19 4:43 AM	4/29/2019	1.2	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	38	KS	left faucet 3 compartment sink	FD	4/24/2019 8:00PM	4/25/19 4:44 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	39	KS	right faucet 3 compartment sink	FD	4/24/2019 8:00PM	4/25/19 4:44 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	40	KS	faucet on food prep table	FD	4/24/2019 8:00PM	4/25/19 4:45 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	41	KS	sprayer by walk ins	FD	4/24/2019 8:00PM	4/25/19 4:45 AM	4/29/2019	2.7	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	42	KS	faucet on 2 compartment sink	FD	4/24/2019 8:00PM	4/25/19 4:46 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	43	KS	sprayer by ice machine	FD	4/24/2019 8:00PM	4/25/19 4:46 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	44	IM	ice machine	FD	4/24/2019 8:00PM	4/25/19 4:48 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	45	KS	faucet on food prep table by walk ins	FD	4/24/2019 8:00PM	4/25/19 4:48 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	46	KS	dual kettle filler	FD	4/24/2019 8:00PM	4/25/19 5:10 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	47	CR	faucet 274	FD	4/24/2019 8:00PM	4/25/19 5:09 AM	4/29/2019	7.7	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	48	CR	faucet 284	FD	4/24/2019 8:00PM	4/25/19 5:10 AM	4/29/2019	11.1	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	49	CR	faucet 285	FD	4/24/2019 8:00PM	4/25/19 5:11 AM	4/29/2019	3.7	No

Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	50	CR	faucet 299	FD	4/24/2019 8:00PM	4/25/19 5:17 AM	4/29/2019	12.9	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	51	CR	faucet 295	FD	4/24/2019 8:00PM	4/25/19 5:59 AM	4/29/2019	1.7	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	52	CR	faucet 216	FD	4/24/2019 8:00PM	4/25/19 4:56 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	53	IM	fridge ice machine 216	FD	4/24/2019 8:00PM	4/25/19 4:57 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	54	IM	ice machine 216	FD	4/24/2019 8:00PM	4/25/19 4:57 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	55	CR	faucet 228	FD	4/24/2019 8:00PM	4/25/19 5:02 AM	4/29/2019	1.9	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	56	CR	faucet 229	FD	4/24/2019 8:00PM	4/25/19 5:04 AM	4/29/2019	3.1	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	2	57	IM	ice machine 239	FD	4/24/2019 8:00PM	4/25/19 5:04 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	3	58	CR	faucet 343	FD	4/24/2019 8:00PM	4/25/19 4:59 AM	4/29/2019	13.1	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	1	59	CR	faucet 104	FD	4/24/2019 8:00PM	4/25/19 4:45 AM	4/29/2019	6.4	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	1	60	CR	faucet 106	FD	4/24/2019 8:00PM	4/25/19 4:40 AM	4/29/2019	15.3	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	1	61	HE	front left faucet 112	FD	4/24/2019 8:00PM	4/25/19 4:43 AM	4/29/2019	11.7	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	1	62	HE	back left faucet 112	FD	4/24/2019 8:00PM	4/25/19 4:43 AM	4/29/2019	3.6	No

Water Testing Laboratory of MD	Patuxent High School	6/10/2019	1	63	HE	middle left faucet 112	FD	4/24/2019 8:00PM	4/25/19 4:43 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	1	64	HE	middle right faucet 112	FD	4/24/2019 8:00PM	4/25/19 4:44 AM	4/29/2019	1.5	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	1	65	HE	back right faucet 112	FD	4/24/2019 8:00PM	4/25/19 4:44 AM	4/29/2019	4.8	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	1	66	HE	front right faucet 112	FD	4/24/2019 8:00PM	4/25/19 4:44 AM	4/29/2019	1.9	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	1	67	TL	teacher faucet 112	FD	4/24/2019 8:00PM	4/25/19 4:45 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	1	68	CR	left faucet 118	FD	4/24/2019 8:00PM	4/25/19 4:49 AM	4/29/2019	2.9	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	1	69	CR	right faucet 118	FD	4/24/2019 8:00PM	4/25/19 4:49 AM	4/29/2019	4	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	1	70	CR	left faucet 120	FD	4/24/2019 8:00PM	4/25/19 4:50 AM	4/29/2019	3.7	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	1	71	CR	right faucet 120	FD	4/24/2019 8:00PM	4/25/19 4:50 AM	4/29/2019	2	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	1	72	CR	faucet adult ED trailer	FD	4/24/2019 8:00PM	4/25/19 5:55 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	1	73	KS	3 compartment sink in Concession Stand	FD	4/24/2019 8:00PM	4/25/19 5:43 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/10/2019	1	74	KS	sink in concession stand	FD	4/24/2019 8:00PM	4/25/19 5:43 AM	4/29/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/22/2019	1	75	CR	Back Left Faucet in Training Room	FD	6/5/19 2:45PM	6/6/2019 5:34AM	6/8/2019	0	No

Water Testing Laboratory of MD	Patuxent High School	6/22/2019	1	76	CR	Back Right Faucet in Training Room	FD	6/5/19 2:45PM	6/6/2019 5:35AM	6/8/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/22/2019	1	77	CR	front Right Faucet in Training Room	FD	6/5/19 2:45PM	6/6/2019 5:35AM	6/8/2019	0	No
Water Testing Laboratory of MD	Patuxent High School	6/22/2019	1	78	IM	Ice Machine in Training Room	FD	6/5/19 2:45PM	6/6/2019 5:37AM	6/8/2019	0	No