

Laboratory Certification ID	Laboratory Name	City/State	Laboratory Certification ID (Laboratory Performing Sample Analysis)	School Name	County	School Type (Code)	School ID	Laboratory Reporting Date	Laboratory Sample ID	School Outlet ID/Floor Plan ID	Building #	Building Name	Building Address	Floor #	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Use (code)	Sample Tap/Outlet Description/Location	Sample Volume (mL)	Sample Type (Code)	Date Water Last Used	Time Water Last Used	Date Sample Collected	Time Sample Collected	Sampler Name	Sampler Telephone number	Analysis Date	Analysis Method	Detection Limit (ppb)	Lead Sample Result (ppb)	≥ 20.5 ppb AL?	Notes
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21127	1	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	DF	CO	water fountain in kindergarden	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:17:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	<1.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21128	2	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	DF	CO	water fountain past main office	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:22:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	<1.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21129	3	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	DF	CO	water fountain outside of room 16	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:24:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	<1.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21130	4	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	DF	CO	water fountain past the gym	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:40:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	<1.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21131	5	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	DF	CO	water fountain by romo 24	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:29:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	<1.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21132	6	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	DF	CO	left water fountain by room 25	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:36:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	<1.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21133	7	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	DF	CO	right water fountain by room 25	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:36:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	<1.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21134	8	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	DF	CO	water fountain by room 31	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:42:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	<1.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21135	9	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	DF	CO	water fountain by room 35	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:48:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	<1.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21136	10	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	DF	CO	water fountain by room 39	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:24:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	1.9	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21137	11	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	DF	CO	water fountain by room 41	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:27:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	<1.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21138	12	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	DF	CO	water fountain by room 45	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:33:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	<1.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21139	13	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	DF	CO	water fountain by room 46	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:37:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	<1.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21140	14	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	DF	CO	water fountain by gym	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:44:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	<1.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21141	15	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	DF	CO	water fountain in cafeteria	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:56:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	<1.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21142	b16	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CF	CO	bubbler in room 11	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:19:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	8.5	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21143	17	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CS	CO	faucet in room 11	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:19:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	4.3	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21144	b18	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CF	CO	bubbler in room 12	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:20:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	1.6	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21145	19	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CS	CO	faucet in room 12	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:20:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	2.5	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21146	b20	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CF	CO	bubbler in room 14	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:26:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	<1.0	No	

Laboratory Certification ID	Laboratory Name	City/State	Laboratory Certification ID (Laboratory Performing Sample Analysis)	School Name	County	School Type (Code)	School ID	Laboratory Reporting Date	Laboratory Sample ID	School Outlet ID/Floor Plan ID	Building #	Building Name	Building Address	Floor #	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Use (code)	Sample Tap/Outlet Description/Location	Sample Volume (mL)	Sample Type (Code)	Date Water Last Used	Time Water Last Used	Date Sample Collected	Time Sample Collected	Sampler Name	Sampler Telephone number	Analysis Date	Analysis Method	Detection Limit (ppb)	Lead Sample Result (ppb)	≥ 20.5 ppb AL?	Notes
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21147	21	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CS	CO	faucet in room 14	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:26:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	<1.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21148	b22	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CF	CO	bubbler in room 15	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:27:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	<1.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21149	23	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CS	CO	faucet in room 15	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:27:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	<1.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21150	24	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CR	CO	faucet in room 18	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:28:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	10.6	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21151	25	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CR	CO	faucet in room 20	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:29:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	3.3	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21152	b26	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CF	CO	bubbler in room 21	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:31:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	3.4	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21153	27	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CS	CO	faucet in room 21	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:31:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	<1.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21154	b28	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CF	CO	bubbler in room 22	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:33:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	1.2	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21155	29	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CS	CO	faucet in room 22	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:33:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	<1.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21156	b30	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CF	CO	bubbler in room 23	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:34:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	1.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21157	31	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CS	CO	faucet in room 23	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:34:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	3.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21158	b32	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CF	CO	bubbler in room 25	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:37:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	<1.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21159	33	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CS	CO	faucet in room 25	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:37:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	<1.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21160	b34	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CF	CO	bubbler in room 26	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:38:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	<1.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21161	35	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CS	CO	faucet in room 26	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:38:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	<1.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21162	b36	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CF	CO	bubbler in room 27	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:40:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	<1.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21163	37	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CS	CO	faucet in room 27	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:40:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	<1.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21164	b38	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CF	CO	bubbler in room 30	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:44:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	1.8	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21165	39	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CS	CO	faucet in room 30	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:44:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	1.3	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21166	b40	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CF	CO	bubbler in room 31	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:47:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	3.8	No	

Laboratory Certification ID	Laboratory Name	City/State	Laboratory Certification ID (Laboratory Performing Sample Analysis)	School Name	County	School Type (Code)	School ID	Laboratory Reporting Date	Laboratory Sample ID	School Outlet ID/Floor Plan ID	Building #	Building Name	Building Address	Floor #	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Use (code)	Sample Tap/Outlet Description/Location	Sample Volume (mL)	Sample Type (Code)	Date Water Last Used	Time Water Last Used	Date Sample Collected	Time Sample Collected	Sampler Name	Sampler Telephone number	Analysis Date	Analysis Method	Detection Limit (ppb)	Lead Sample Result (ppb)	≥ 20.5 ppb AL?	Notes
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21167	41	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CS	CO	faucet in room 31	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:47:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	5.1	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21168	b42	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CF	CO	bubbler in room 32	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:49:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	5.5	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21169	43	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CS	CO	faucet in room 32	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:49:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	4.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21170	b44	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CF	CO	bubbler in room 33	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:51:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	2.1	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21171	45	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CS	CO	faucet in room 33	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:51:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	3.7	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21172	b46	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CF	CO	bubbler in room 34	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:52:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	11.2	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21173	47	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CS	CO	faucet in room 34	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:52:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	6.3	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21174	b48	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CF	CO	bubbler in room 36	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:53:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	2.5	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21175	49	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CS	CO	faucet in room 36	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:53:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	3.2	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21176	b50	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CF	CO	bubbler in room 38	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:23:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	12.6	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21177	51	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CS	CO	faucet in room 38	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:23:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	4.6	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21178	b52	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CF	CO	bubbler in room 39	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:25:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	12.2	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21179	53	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CS	CO	faucet in room 39	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:25:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	9.3	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21180	b54	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CF	CO	bubble in room 40	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:26:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	6.6	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21181	55	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CS	CO	faucet in room 40	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:26:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	3.9	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21182	b56	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CF	CO	bubbler in room 41	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:28:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	5.9	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21183	57	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CS	CO	faucet in room 41	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:28:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	3.1	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21184	b58	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CF	CO	bubbler in room 42	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:29:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	2.7	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21185	59	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CS	CO	faucet in room 42	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:29:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	3.9	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21186	b60	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CF	CO	bubbler in room 43	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:30:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	2.9	No	

Laboratory Certification ID	Laboratory Name	City/State	Laboratory Certification ID (Laboratory Performing Sample Analysis)	School Name	County	School Type (Code)	School ID 09-____-____	Laboratory Reporting Date	Laboratory Sample ID	School Outlet ID/Floor Plan ID	Building #	Building Name	Building Address	Floor #	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Use (code)	Sample Tap/Outlet Description/Location	Sample Volume (mL)	Sample Type (Code)	Date Water Last Used	Time Water Last Used	Date Sample Collected	Time Sample Collected	Sampler Name	Sampler Telephone number	Analysis Date	Analysis Method	Detection Limit (ppb)	Lead Sample Result (ppb)	≥ 20.5 ppb AL?	Notes
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21187	51	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CS	CO	faucet in room 43	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:30:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	2.9	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21188	b62	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CF	CO	bubbler in room 44	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:32:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	2.8	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21189	63	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CS	CO	faucet in room 44	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:32:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	4.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21190	b64	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CF	CO	bubbler in room 45	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:33:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	2.3	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21191	65	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CS	CO	faucet in room 45	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:33:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	3.4	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21192	b66	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CF	CO	bubbler in room 46	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:35:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	3.1	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21193	67	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CS	CO	faucet in room 46	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:35:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	2.8	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21194	b68	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CF	CO	bubbler in room 47	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:36:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	6.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21195	69	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CS	CO	faucet in room 47	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:36:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	5.2	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21196	b70	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CF	CO	bubbler in room 48	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:37:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	2.5	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21197	71	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CS	CO	faucet in room 48	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:37:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	3.5	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21198	b72	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CF	CO	bubbler in room 50	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:39:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	2.3	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21199	73	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CS	CO	faucet in room 50	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:39:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	2.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21200	74	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	TL	CO	faucet in lounge	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:41:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	1.8	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21201	75	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CR	CO	left faucet in room 54	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:42:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	3.3	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21202	76	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CR	CO	right faucet in room 54	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:42:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	1.1	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21203	b77	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CF	CO	bubbler in room 55	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:43:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	2.9	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21204	78	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CS	CO	facuet in room 55	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:43:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	4.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21205	79	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	KS	CO	solo faucet in kitchen	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:46:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	5.4	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21206	80	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	KS	CO	left faucet in kitchen	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:46:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	3.5	No	

Laboratory Certification ID	Laboratory Name	City/State	Laboratory Certification ID (Laboratory Performing Sample Analysis)	School Name	County	School Type (Code)	School ID	Laboratory Reporting Date	Laboratory Sample ID	School Outlet ID/Floor Plan ID	Building #	Building Name	Building Address	Floor #	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Use (code)	Sample Tap/Outlet Description/Location	Sample Volume (mL)	Sample Type (Code)	Date Water Last Used	Time Water Last Used	Date Sample Collected	Time Sample Collected	Sampler Name	Sampler Telephone number	Analysis Date	Analysis Method	Detection Limit (ppb)	Lead Sample Result (ppb)	≥ 20.5 ppb AL?	Notes
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21207	81	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	KS	CO	right faucet in kitchen	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:46:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	4.2	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21208	82	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	NO	CO	faucet in nurse office	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:49:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	<1.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21209	83	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	TL	CO	faucet record room 3	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:49:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	<1.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21210	84	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	CR	CO	left faucet in head start	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:57:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	1.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21211	85	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	DF	CO	water fountain in head start	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:57:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	<1.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21212	86	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	DF	CO	outside fountain at the playground	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:23:00 AM	Lonnie Smith	410-535-1800	5/18/2018	200.9	1	<1.0	No	
MD-214	Water Testing Laboratory of MD	Stevensville, MD	MD-214	Plum Point Elementary	Calvert	P	04.015	6/23/2018	K21213	87	1	Main Building	1245 Plum Point Rd Huntingtown, MD	1	IM	CO	ice machine in kitchen	250	FD	5/14/2018	6:30:00 PM	5/15/2018	5:46:00 AM	Chris Mlinaric	410-535-1800	5/18/2018	200.9	1	<1.0	No	

Joy Ostroff Shields



Laboratory Manager