

St. Leonard Elementary School

2018-2019 Testing Results

Laboratory Name	School Name	Laboratory Reporting Date	Floor #	School Outlet ID/Floor Plan ID	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Description/Location	Sample Type (Code)	Date Water Last Used	Time Water Last Used	Date Sample Collected	Time Sample Collected	Analysis Date	Lead Sample Result (ppb)	≥ 20.5 ppb AL?
Water Testing Laboratory of MD	St. Leonard Elementary School	2/23/2019	1	53*	CS	faucet in 108	FD	2/5/2019	5:45:00 PM	2/6/2019	6:57:00 AM	2/14/2019	<1.0	No
Water Testing Laboratory of MD	St. Leonard Elementary School	2/23/2019	1	57**	CS	faucet in 101	FD	2/5/2019	5:45:00 PM	2/6/2019	6:55:00 AM	2/14/2019	<1.0	No

Notes: Sample Sites 53 and 57 had the faucets replaced in February 2019

2017-2018 Testing Results

Laboratory Name	School Name	Laboratory Reporting Date	Floor #	School Outlet ID/Floor Plan ID	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Description/Location	Sample Type (Code)	Date Water Last Used	Time Water Last Used	Date Sample Collected	Time Sample Collected	Analysis Date	Lead Sample Result (ppb)	≥ 20.5 ppb AL?
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	1	DF	fountain in cafeteria	FD	4/19/2018	7:00:00 PM	4/20/2018	5:35:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	2	DF	fountain outside of gym	FD	4/19/2018	7:00:00 PM	4/20/2018	5:42:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	3	DF	fountain in gym	FD	4/19/2018	7:00:00 PM	4/20/2018	5:43:00 AM	5/1/2018	<1.0	no

Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	4	DF	left fountain by 112	FD	4/19/2018	7:00:00 PM	4/20/2018	6:06:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	5	DF	right fountain by 112	FD	4/19/2018	7:00:00 PM	4/20/2018	6:06:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	6	DF	fountain outside B 05	FD	4/19/2018	7:00:00 PM	4/20/2018	5:42:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	7	DF	fountain by B 06	FD	4/19/2018	7:00:00 PM	4/20/2018	5:40:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	8	DF	fountain in nurse room	FD	4/19/2018	7:00:00 PM	4/20/2018	5:29:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	9	DF	fountain in office work room	FD	4/19/2018	7:00:00 PM	4/20/2018	5:31:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	10	CR	closest faucet in 130	FD	4/19/2018	7:00:00 PM	4/20/2018	5:32:00 AM	5/1/2018	1.60	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	11	CR	far faucet in 130	FD	4/19/2018	7:00:00 PM	4/20/2018	5:32:00 AM	5/1/2018	2.10	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b12	CF	bubbler in 128	FD	4/19/2018	7:00:00 PM	4/20/2018	5:34:00 AM	5/1/2018	<1.0	no
Water Testing	St Leonard Elementary	6/2/2018	1	13	CS	faucet in 128	FD	4/19/2018	7:00:00 PM	4/20/2018	5:34:00 AM	5/1/2018	1.40	no

Laboratory of MD														
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	14	TL	faucet in staff lounge	FD	4/19/2018	7:00:00 PM	4/20/2018	5:35:00 AM	5/1/2018	1.40	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	15	KS	left faucet in kitchen	FD	4/19/2018	7:00:00 PM	4/20/2018	5:38:00 AM	5/1/2018	1.30	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	16	KS	right faucet in kitchen	FD	4/19/2018	7:00:00 PM	4/20/2018	5:38:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	17	KS	solo faucet, 2 compartment sink	FD	4/19/2018	7:00:00 PM	4/20/2018	5:38:00 AM	5/1/2018	1.60	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b18	CF	bubbler room 127	FD	4/19/2018	7:00:00 PM	4/20/2018	5:45:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	19	CS	faucet in 127	FD	4/19/2018	7:00:00 PM	4/20/2018	5:45:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b20	CF	bubbler in 126	FD	4/19/2018	7:00:00 PM	4/20/2018	5:47:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	21	CS	faucet in 126	FD	4/19/2018	7:00:00 PM	4/20/2018	5:48:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b22	CF	bubbler in 125	FD	4/19/2018	7:00:00 PM	4/20/2018	5:48:00 AM	5/1/2018	<1.0	no

Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	23	CS	faucet in 125	FD	4/19/2018	7:00:00 PM	4/20/2018	5:48:00 AM	5/1/2018	1.50	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	24	CR	faucet outside 125	FD	4/19/2018	7:00:00 PM	4/20/2018	5:44:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b25	CF	bubbler in 124	FD	4/19/2018	7:00:00 PM	4/20/2018	5:50:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	26	CS	faucet in 124	FD	4/19/2018	7:00:00 PM	4/20/2018	5:50:00 AM	5/1/2018	1.30	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b27	CF	bubbler in 123	FD	4/19/2018	7:00:00 PM	4/20/2018	5:51:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	28	CS	faucet in 123	FD	4/19/2018	7:00:00 PM	4/20/2018	5:51:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	29	TL	faucet in media workroom	FD	4/19/2018	7:00:00 PM	4/20/2018	5:41:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b30	CF	bubbler in 122	FD	4/19/2018	7:00:00 PM	4/20/2018	5:53:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	31	CS	faucet in 122	FD	4/19/2018	7:00:00 PM	4/20/2018	5:53:00 AM	5/1/2018	1.40	no
Water Testing	St Leonard Elementary	6/2/2018	1	b32	CF	bubbler in 121	FD	4/19/2018	7:00:00 PM	4/20/2018	5:54:00 AM	5/1/2018	<1.0	no

Laboratory of MD														
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	33	CS	faucet in 121	FD	4/19/2018	7:00:00 PM	4/20/2018	5:54:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b34	CF	bubbler in 120	FD	4/19/2018	7:00:00 PM	4/20/2018	5:58:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	35	CS	faucet in 120	FD	4/19/2018	7:00:00 PM	4/20/2018	5:58:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b36	CF	bubbler in 119	FD	4/19/2018	7:00:00 PM	4/20/2018	6:00:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	37	CS	faucet in 119	FD	4/19/2018	7:00:00 PM	4/20/2018	6:00:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b38	CF	bubbler in 118	FD	4/19/2018	7:00:00 PM	4/20/2018	6:01:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	39	CS	faucet in 118	FD	4/19/2018	7:00:00 PM	4/20/2018	6:01:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	40	CR	faucet between 120	FD	4/19/2018	7:00:00 PM	4/20/2018	6:02:00 AM	5/1/2018	1.50	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b41	CF	bubbler in 117	FD	4/19/2018	7:00:00 PM	4/20/2018	6:09:00 AM	5/1/2018	2.30	no

Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	42	CS	faucet in 117	FD	4/19/2018	7:00:00 PM	4/20/2018	6:09:00 AM	5/1/2018	3.20	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b43	CF	bubbler in 116	FD	4/19/2018	7:00:00 PM	4/20/2018	6:10:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	44	CS	faucet in 116	FD	4/19/2018	7:00:00 PM	4/20/2018	6:10:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b45	CF	bubbler in 115	FD	4/19/2018	7:00:00 PM	4/20/2018	6:11:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	CS	46	DF	faucet in 115	FD	4/19/2018	7:00:00 PM	4/20/2018	6:11:00 AM	5/1/2018	1.10	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b47	CF	bubbler in 114	FD	4/19/2018	7:00:00 PM	4/20/2018	6:13:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	48	CS	faucet in 114	FD	4/19/2018	7:00:00 PM	4/20/2018	6:13:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b49	CF	bubbler in 113	FD	4/19/2018	7:00:00 PM	4/20/2018	6:15:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	50	CS	faucet in 113	FD	4/19/2018	7:00:00 PM	4/20/2018	6:15:00 AM	5/1/2018	1.80	no
Water Testing	St Leonard Elementary	6/2/2018	1	51	CR	faucet between 115	FD	4/19/2018	7:00:00 PM	4/20/2018	6:15:00 AM	5/2/2018	2.10	no

Laboratory of MD														
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b52	CF	bubbler in 108	FD	4/19/2018	7:00:00 PM	4/20/2018	6:10:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	53*	CS	faucet in 108	FD	4/19/2018	7:00:00 PM	4/20/2018	6:10:00 AM	5/2/2018	5.30	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b54	CF	bubbler in 107	FD	4/19/2018	7:00:00 PM	4/20/2018	6:08:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	55	CS	faucet in 107	FD	4/19/2018	7:00:00 PM	4/20/2018	6:08:00 AM	5/2/2018	1.30	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b56	CF	bubbler in 101	FD	4/19/2018	7:00:00 PM	4/20/2018	6:06:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	57**	CS	faucet in 101	FD	4/19/2018	7:00:00 PM	4/20/2018	6:06:00 AM	5/2/2018	6.80	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b58	CF	bubbler in 102	FD	4/19/2018	7:00:00 PM	4/20/2018	6:05:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	59	CS	faucet in 102	FD	4/19/2018	7:00:00 PM	4/20/2018	6:05:00 AM	5/2/2018	2.10	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b60	CF	bubbler in 133	FD	4/19/2018	7:00:00 PM	4/20/2018	6:03:00 AM	5/2/2018	<1.0	no

Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	61	CS	faucet in 133	FD	4/19/2018	7:00:00 PM	4/20/2018	6:01:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b62	CF	bubbler in 134	FD	4/19/2018	7:00:00 PM	4/20/2018	6:01:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	63	CS	faucet in 134	FD	4/19/2018	7:00:00 PM	4/20/2018	5:31:00 AM	5/2/2018	1.90	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b64	CF	bubbler in B10	FD	4/19/2018	7:00:00 PM	4/20/2018	5:31:00 AM	5/2/2018	2.00	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	65	CS	faucet in B10	FD	4/19/2018	7:00:00 PM	4/20/2018	5:31:00 AM	5/2/2018	1.30	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b66	CF	bubbler in B09	FD	4/19/2018	7:00:00 PM	4/20/2018	5:33:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	67	CS	faucet in B09	FD	4/19/2018	7:00:00 PM	4/20/2018	5:33:00 AM	5/2/2018	1.30	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b68	CF	bubbler in B08	FD	4/19/2018	7:00:00 PM	4/20/2018	5:35:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	69	CS	faucet in B08	FD	4/19/2018	7:00:00 PM	4/20/2018	5:35:00 AM	5/2/2018	1.60	no
Water Testing	St Leonard Elementary	6/2/2018	1	b70	CF	bubbler in B07	FD	4/19/2018	7:00:00 PM	4/20/2018	6:28:00 AM	5/2/2018	1.40	no

Laboratory of MD														
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	71	CS	faucet in B07	FD	4/19/2018	7:00:00 PM	4/20/2018	6:28:00 AM	5/2/2018	3.00	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b72	CF	bubbler in B06	FD	4/19/2018	7:00:00 PM	4/20/2018	5:39:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	73	CR	faucet in B06	FD	4/19/2018	7:00:00 PM	4/20/2018	5:39:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	74	CR	faucet between B08	FD	4/19/2018	7:00:00 PM	4/20/2018	5:36:00 AM	5/2/2018	1.10	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b75	CF	bubbler in B05	FD	4/19/2018	7:00:00 PM	4/20/2018	5:44:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	76	CS	faucet in B05	FD	4/19/2018	7:00:00 PM	4/20/2018	5:44:00 AM	5/2/2018	1.10	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b77	CF	bubbler in B04	FD	4/19/2018	7:00:00 PM	4/20/2018	5:45:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	78	CS	faucet in B04	FD	4/19/2018	7:00:00 PM	4/20/2018	5:45:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b79	CF	bubbler in B03	FD	4/19/2018	7:00:00 PM	4/20/2018	5:48:00 AM	5/2/2018	<1.0	no

Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	80	CS	faucet in B03	FD	4/19/2018	7:00:00 PM	4/20/2018	5:48:00 AM	5/2/2018	1.00	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b81	CF	bubbler in B02	FD	4/19/2018	7:00:00 PM	4/20/2018	5:50:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	82	CS	faucet in B02	FD	4/19/2018	7:00:00 PM	4/20/2018	5:50:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b83	CF	bubbler in B01	FD	4/19/2018	7:00:00 PM	4/20/2018	5:53:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	84	CS	faucet in B01	FD	4/19/2018	7:00:00 PM	4/20/2018	5:53:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	85	CR	faucet between B03	FD	4/19/2018	7:00:00 PM	4/20/2018	5:49:00 AM	5/2/2018	1.30	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	86	DF	fountain outside by black top	FD	4/19/2018	7:00:00 PM	4/20/2018	6:40:00 AM	5/2/2018	1.80	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	87	IM	small ice machine in health room	FD	4/19/2018	7:00:00 PM	4/20/2018	5:30:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	88	IM	ice machine in fridge freezer combo	FD	4/19/2018	7:00:00 PM	4/20/2018	5:30:00 AM	5/2/2018	<1.0	no
Water Testing	St Leonard Elementary	6/2/2018	1	89	DF	water fountain in 102	FD	4/20/2018	6:30:00 AM	4/20/2018	2:33:00 PM	5/2/2018	<1.0	no

Laboratory of MD														
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	1	DF	fountain in cafeteria	FD	4/19/2018	7:00:00 PM	4/20/2018	5:35:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	2	DF	fountain outside of gym	FD	4/19/2018	7:00:00 PM	4/20/2018	5:42:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	3	DF	fountain in gym	FD	4/19/2018	7:00:00 PM	4/20/2018	5:43:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	4	DF	left fountain by 112	FD	4/19/2018	7:00:00 PM	4/20/2018	6:06:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	5	DF	right fountain by 112	FD	4/19/2018	7:00:00 PM	4/20/2018	6:06:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	6	DF	fountain outside B 05	FD	4/19/2018	7:00:00 PM	4/20/2018	5:42:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	7	DF	fountain by B 06	FD	4/19/2018	7:00:00 PM	4/20/2018	5:40:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	8	DF	fountain in nurse room	FD	4/19/2018	7:00:00 PM	4/20/2018	5:29:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	9	DF	fountain in office work room	FD	4/19/2018	7:00:00 PM	4/20/2018	5:31:00 AM	5/1/2018	<1.0	no

Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	10	CR	closest faucet in 130	FD	4/19/2018	7:00:00 PM	4/20/2018	5:32:00 AM	5/1/2018	1.60	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	11	CR	far faucet in 130	FD	4/19/2018	7:00:00 PM	4/20/2018	5:32:00 AM	5/1/2018	2.10	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b12	CF	bubbler in 128	FD	4/19/2018	7:00:00 PM	4/20/2018	5:34:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	13	CS	faucet in 128	FD	4/19/2018	7:00:00 PM	4/20/2018	5:34:00 AM	5/1/2018	1.40	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	14	TL	faucet in staff lounge	FD	4/19/2018	7:00:00 PM	4/20/2018	5:35:00 AM	5/1/2018	1.40	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	15	KS	left faucet in kitchen	FD	4/19/2018	7:00:00 PM	4/20/2018	5:38:00 AM	5/1/2018	1.30	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	16	KS	right faucet in kitchen	FD	4/19/2018	7:00:00 PM	4/20/2018	5:38:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	17	KS	solo faucet, 2 compartment sink	FD	4/19/2018	7:00:00 PM	4/20/2018	5:38:00 AM	5/1/2018	1.60	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b18	CF	bubbler room 127	FD	4/19/2018	7:00:00 PM	4/20/2018	5:45:00 AM	5/1/2018	<1.0	no
Water Testing	St Leonard Elementary	6/2/2018	1	19	CS	faucet in 127	FD	4/19/2018	7:00:00 PM	4/20/2018	5:45:00 AM	5/1/2018	<1.0	no

Laboratory of MD														
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b20	CF	bubbler in 126	FD	4/19/2018	7:00:00 PM	4/20/2018	5:47:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	21	CS	faucet in 126	FD	4/19/2018	7:00:00 PM	4/20/2018	5:48:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b22	CF	bubbler in 125	FD	4/19/2018	7:00:00 PM	4/20/2018	5:48:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	23	CS	faucet in 125	FD	4/19/2018	7:00:00 PM	4/20/2018	5:48:00 AM	5/1/2018	1.50	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	24	CR	faucet outside 125	FD	4/19/2018	7:00:00 PM	4/20/2018	5:44:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b25	CF	bubbler in 124	FD	4/19/2018	7:00:00 PM	4/20/2018	5:50:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	26	CS	faucet in 124	FD	4/19/2018	7:00:00 PM	4/20/2018	5:50:00 AM	5/1/2018	1.30	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b27	CF	bubbler in 123	FD	4/19/2018	7:00:00 PM	4/20/2018	5:51:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	28	CS	faucet in 123	FD	4/19/2018	7:00:00 PM	4/20/2018	5:51:00 AM	5/1/2018	<1.0	no

Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	29	TL	faucet in media workroom	FD	4/19/2018	7:00:00 PM	4/20/2018	5:41:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b30	CF	bubbler in 122	FD	4/19/2018	7:00:00 PM	4/20/2018	5:53:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	31	CS	faucet in 122	FD	4/19/2018	7:00:00 PM	4/20/2018	5:53:00 AM	5/1/2018	1.40	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b32	CF	bubbler in 121	FD	4/19/2018	7:00:00 PM	4/20/2018	5:54:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	33	CS	faucet in 121	FD	4/19/2018	7:00:00 PM	4/20/2018	5:54:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b34	CF	bubbler in 120	FD	4/19/2018	7:00:00 PM	4/20/2018	5:58:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	35	CS	faucet in 120	FD	4/19/2018	7:00:00 PM	4/20/2018	5:58:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b36	CF	bubbler in 119	FD	4/19/2018	7:00:00 PM	4/20/2018	6:00:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	37	CS	faucet in 119	FD	4/19/2018	7:00:00 PM	4/20/2018	6:00:00 AM	5/1/2018	<1.0	no
Water Testing	St Leonard Elementary	6/2/2018	1	b38	CF	bubbler in 118	FD	4/19/2018	7:00:00 PM	4/20/2018	6:01:00 AM	5/1/2018	<1.0	no

Laboratory of MD														
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	39	CS	faucet in 118	FD	4/19/2018	7:00:00 PM	4/20/2018	6:01:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	40	CR	faucet between 120	FD	4/19/2018	7:00:00 PM	4/20/2018	6:02:00 AM	5/1/2018	1.50	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b41	CF	bubbler in 117	FD	4/19/2018	7:00:00 PM	4/20/2018	6:09:00 AM	5/1/2018	2.30	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	42	CS	faucet in 117	FD	4/19/2018	7:00:00 PM	4/20/2018	6:09:00 AM	5/1/2018	3.20	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b43	CF	bubbler in 116	FD	4/19/2018	7:00:00 PM	4/20/2018	6:10:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	44	CS	faucet in 116	FD	4/19/2018	7:00:00 PM	4/20/2018	6:10:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b45	CF	bubbler in 115	FD	4/19/2018	7:00:00 PM	4/20/2018	6:11:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	CS	46	DF	faucet in 115	FD	4/19/2018	7:00:00 PM	4/20/2018	6:11:00 AM	5/1/2018	1.10	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b47	CF	bubbler in 114	FD	4/19/2018	7:00:00 PM	4/20/2018	6:13:00 AM	5/1/2018	<1.0	no

Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	48	CS	faucet in 114	FD	4/19/2018	7:00:00 PM	4/20/2018	6:13:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b49	CF	bubbler in 113	FD	4/19/2018	7:00:00 PM	4/20/2018	6:15:00 AM	5/1/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	50	CS	faucet in 113	FD	4/19/2018	7:00:00 PM	4/20/2018	6:15:00 AM	5/1/2018	1.80	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	51	CR	faucet between 115	FD	4/19/2018	7:00:00 PM	4/20/2018	6:15:00 AM	5/2/2018	2.10	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b52	CF	bubbler in 108	FD	4/19/2018	7:00:00 PM	4/20/2018	6:10:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	53*	CS	faucet in 108	FD	4/19/2018	7:00:00 PM	4/20/2018	6:10:00 AM	5/2/2018	5.30	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b54	CF	bubbler in 107	FD	4/19/2018	7:00:00 PM	4/20/2018	6:08:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	55	CS	faucet in 107	FD	4/19/2018	7:00:00 PM	4/20/2018	6:08:00 AM	5/2/2018	1.30	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b56	CF	bubbler in 101	FD	4/19/2018	7:00:00 PM	4/20/2018	6:06:00 AM	5/2/2018	<1.0	no
Water Testing	St Leonard Elementary	6/2/2018	1	57**	CS	faucet in 101	FD	4/19/2018	7:00:00 PM	4/20/2018	6:06:00 AM	5/2/2018	6.80	no

Laboratory of MD														
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b58	CF	bubbler in 102	FD	4/19/2018	7:00:00 PM	4/20/2018	6:05:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	59	CS	faucet in 102	FD	4/19/2018	7:00:00 PM	4/20/2018	6:05:00 AM	5/2/2018	2.10	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b60	CF	bubbler in 133	FD	4/19/2018	7:00:00 PM	4/20/2018	6:03:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	61	CS	faucet in 133	FD	4/19/2018	7:00:00 PM	4/20/2018	6:01:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b62	CF	bubbler in 134	FD	4/19/2018	7:00:00 PM	4/20/2018	6:01:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	63	CS	faucet in 134	FD	4/19/2018	7:00:00 PM	4/20/2018	5:31:00 AM	5/2/2018	1.90	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b64	CF	bubbler in B10	FD	4/19/2018	7:00:00 PM	4/20/2018	5:31:00 AM	5/2/2018	2.00	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	65	CS	faucet in B10	FD	4/19/2018	7:00:00 PM	4/20/2018	5:31:00 AM	5/2/2018	1.30	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b66	CF	bubbler in B09	FD	4/19/2018	7:00:00 PM	4/20/2018	5:33:00 AM	5/2/2018	<1.0	no

Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	67	CS	faucet in B09	FD	4/19/2018	7:00:00 PM	4/20/2018	5:33:00 AM	5/2/2018	1.30	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b68	CF	bubbler in B08	FD	4/19/2018	7:00:00 PM	4/20/2018	5:35:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	69	CS	faucet in B08	FD	4/19/2018	7:00:00 PM	4/20/2018	5:35:00 AM	5/2/2018	1.60	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b70	CF	bubbler in B07	FD	4/19/2018	7:00:00 PM	4/20/2018	6:28:00 AM	5/2/2018	1.40	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	71	CS	faucet in B07	FD	4/19/2018	7:00:00 PM	4/20/2018	6:28:00 AM	5/2/2018	3.00	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b72	CF	bubbler in B06	FD	4/19/2018	7:00:00 PM	4/20/2018	5:39:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	73	CR	faucet in B06	FD	4/19/2018	7:00:00 PM	4/20/2018	5:39:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	74	CR	faucet between B08	FD	4/19/2018	7:00:00 PM	4/20/2018	5:36:00 AM	5/2/2018	1.10	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b75	CF	bubbler in B05	FD	4/19/2018	7:00:00 PM	4/20/2018	5:44:00 AM	5/2/2018	<1.0	no
Water Testing	St Leonard Elementary	6/2/2018	1	76	CS	faucet in B05	FD	4/19/2018	7:00:00 PM	4/20/2018	5:44:00 AM	5/2/2018	1.10	no

Laboratory of MD														
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b77	CF	bubbler in B04	FD	4/19/2018	7:00:00 PM	4/20/2018	5:45:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	78	CS	faucet in B04	FD	4/19/2018	7:00:00 PM	4/20/2018	5:45:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b79	CF	bubbler in B03	FD	4/19/2018	7:00:00 PM	4/20/2018	5:48:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	80	CS	faucet in B03	FD	4/19/2018	7:00:00 PM	4/20/2018	5:48:00 AM	5/2/2018	1.00	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b81	CF	bubbler in B02	FD	4/19/2018	7:00:00 PM	4/20/2018	5:50:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	82	CS	faucet in B02	FD	4/19/2018	7:00:00 PM	4/20/2018	5:50:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	b83	CF	bubbler in B01	FD	4/19/2018	7:00:00 PM	4/20/2018	5:53:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	84	CS	faucet in B01	FD	4/19/2018	7:00:00 PM	4/20/2018	5:53:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	85	CR	faucet between B03	FD	4/19/2018	7:00:00 PM	4/20/2018	5:49:00 AM	5/2/2018	1.30	no

Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	86	DF	fountain outside by black top	FD	4/19/2018	7:00:00 PM	4/20/2018	6:40:00 AM	5/2/2018	1.80	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	87	IM	small ice machine in health room	FD	4/19/2018	7:00:00 PM	4/20/2018	5:30:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	88	IM	ice machine in fridge freezer combo	FD	4/19/2018	7:00:00 PM	4/20/2018	5:30:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	St Leonard Elementary	6/2/2018	1	89	DF	water fountain in 102	FD	4/20/2018	6:30:00 AM	4/20/2018	2:33:00 PM	5/2/2018	<1.0	no