

# Windy Hill Elementary School

## 2018-2019 Testing Results

Laboratory Name	School Name	Laboratory Reporting Date	Floor #	School Outlet ID/Floor Plan ID	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Description/Location	Sample Type (Code)	Date Water Last Used	Time Water Last Used	Date Sample Collected	Time Sample Collected	Analysis Date	Lead Sample Result (ppb)	≥ 20.5 ppb AL?
Water Testing Laboratory of MD	St. Leonard Elementary School	2/23/2019	1	53*	CS	faucet in 108	FD	2/5/2019	5:45:00 PM	2/6/2019	6:57:00 AM	2/14/2019	<1.0	No
Water Testing Laboratory of MD	St. Leonard Elementary School	2/23/2019	1	57**	CS	faucet in 101	FD	2/5/2019	5:45:00 PM	2/6/2019	6:55:00 AM	2/14/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary	2/23/2019	1	70***	CS	faucet in 97	FD	2/5/2019	5:20:00 PM	2/6/2019	6:32:00 AM	2/14/2019	<1.0	No

Notes: Sample Sites 44, 54 and 70 had the faucets replaced in February 2019

## 2017-2018 Testing Results

Laboratory Name	School Name	Laboratory Reporting Date	Floor #	School Outlet ID/Floor Plan ID	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Description/Location	Sample Type (Code)	Date Water Last Used	Time Water Last Used	Date Sample Collected	Time Sample Collected	Analysis Date	Lead Sample Result (ppb)	≥ 20.5 ppb AL?
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	1	DF	fountain past main office	FD	4/25/2018	6:15:00 PM	4/26/2018	5:08:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	2	DF	fountain between 27 and 46	FD	4/25/2018	6:15:00 PM	4/26/2018	5:07:00 AM	5/2/2018	<1.0	no

Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	3	DF	fountain outside of gym	FD	4/25/2018	6:15:00 PM	4/26/2018	5:09:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	4	DF	fountain across from 47	FD	4/25/2018	6:15:00 PM	4/26/2018	5:20:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	5	DF	fountain across from 69	FD	4/25/2018	6:15:00 PM	4/26/2018	5:33:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	6	DF	fountain in gym	FD	4/25/2018	6:15:00 PM	4/26/2018	5:02:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	7	DF	fountain in cafeteria	FD	4/25/2018	6:15:00 PM	4/26/2018	5:03:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b8	CF	bubbler in 24	FD	4/25/2018	6:15:00 PM	4/26/2018	4:59:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	9	CS	fountain in 24	FD	4/25/2018	6:15:00 PM	4/26/2018	4:59:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b10	CF	bubbler in 25	FD	4/25/2018	6:15:00 PM	4/26/2018	5:01:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	11	CS	fountain in 25	FD	4/25/2018	6:15:00 PM	4/26/2018	5:01:00 AM	5/2/2018	<1.0	no
Water Testing	Windy Hill Elementary	6/2/2018	1	b12	CF	bubbler in 26	FD	4/25/2018	6:15:00 PM	4/26/2018	5:03:00 AM	5/2/2018	<1.0	no

Laboratory of MD														
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	13	CS	faucet in 26	FD	4/25/2018	6:15:00 PM	4/26/2018	5:03:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b14	CF	bubbler in 27	FD	4/25/2018	6:15:00 PM	4/26/2018	5:04:00 AM	5/2/2018	1.40	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	15	CS	faucet in 27	FD	4/25/2018	6:15:00 PM	4/26/2018	5:04:00 AM	5/2/2018	1.80	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b16	CF	bubbler in 42	FD	4/25/2018	6:15:00 PM	4/26/2018	5:10:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	17	CS	faucet in 42	FD	4/25/2018	6:15:00 PM	4/26/2018	5:10:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b18	CF	bubbler in 43	FD	4/25/2018	6:15:00 PM	4/26/2018	5:12:00 AM	5/2/2018	4.00	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	19	CS	faucet in 43	FD	4/25/2018	6:15:00 PM	4/26/2018	5:12:00 AM	5/2/2018	2.40	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b20	CF	bubbler in 44	FD	4/25/2018	6:15:00 PM	4/26/2018	5:13:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	21	CS	faucet in 44	FD	4/25/2018	6:15:00 PM	4/26/2018	5:13:00 AM	5/2/2018	<1.0	no

Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b22	CF	bubbler in 45	FD	4/25/2018	6:15:00 PM	4/26/2018	5:13:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	23	CS	faucet in 45	FD	4/25/2018	6:15:00 PM	4/26/2018	5:15:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b24	CF	bubble in 46	FD	4/25/2018	6:15:00 PM	4/26/2018	5:18:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	25	CS	faucet in 46	FD	4/25/2018	6:15:00 PM	4/26/2018	5:18:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	26	CR	faucet in 29	FD	4/25/2018	6:15:00 PM	4/26/2018	5:19:00 AM	5/2/2018	1.80	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b27	CF	bubbler in 47	FD	4/25/2018	6:15:00 PM	4/26/2018	5:21:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	28	CS	faucet in 47	FD	4/25/2018	6:15:00 PM	4/26/2018	5:21:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b29	CF	bubbler in 48	FD	4/25/2018	6:15:00 PM	4/26/2018	5:23:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	30	CS	faucet in 48	FD	4/25/2018	6:15:00 PM	4/26/2018	5:23:00 AM	5/2/2018	<1.0	no
Water Testing	Windy Hill Elementary	6/2/2018	1	b31	CF	bubbler in 49	FD	4/25/2018	6:15:00 PM	4/26/2018	5:24:00 AM	5/2/2018	<1.0	no

Laboratory of MD														
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	32	CS	faucet in 49	FD	4/25/2018	6:15:00 PM	4/26/2018	5:24:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b33	CF	bubbler in 50	FD	4/25/2018	6:15:00 PM	4/26/2018	5:27:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	34	CS	faucet in 50	FD	4/25/2018	6:15:00 PM	4/26/2018	5:27:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b35	CF	bubbler in 51	FD	4/25/2018	6:15:00 PM	4/26/2018	5:29:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	36	CS	faucet in 51	FD	4/25/2018	6:15:00 PM	4/26/2018	5:29:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	2	b37	CF	bubbler in 201	FD	4/25/2018	6:15:00 PM	4/26/2018	5:30:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	2	38	CS	faucet in 201	FD	4/25/2018	6:15:00 PM	4/26/2018	5:30:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	2	b39	CF	bubbler in 202	FD	4/25/2018	6:15:00 PM	4/26/2018	5:33:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	2	40	CS	faucet in 202	FD	4/25/2018	6:15:00 PM	4/26/2018	5:33:00 AM	5/2/2018	<1.0	no

Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b41	CF	bubbler in 60	FD	4/25/2018	6:15:00 PM	4/26/2018	5:35:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	42	CS	faucet in 60	FD	4/25/2018	6:15:00 PM	4/26/2018	5:35:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b43	CF	bubbler in 70	FD	4/25/2018	6:15:00 PM	4/26/2018	5:35:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	44*	CS	faucet in 70	FD	4/25/2018	6:15:00 PM	4/26/2018	5:35:00 AM	5/2/2018	9.00	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b45	CF	bubbler in 69	FD	4/25/2018	6:15:00 PM	4/26/2018	5:34:00 AM	5/2/2018	1.70	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	46	CS	faucet in 69	FD	4/25/2018	6:15:00 PM	4/26/2018	5:34:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b47	CF	bubbler in 72	FD	4/25/2018	6:15:00 PM	4/26/2018	5:31:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	48	CS	faucet in 72	FD	4/25/2018	6:15:00 PM	4/26/2018	5:31:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b49	CF	bubbler in 71	FD	4/25/2018	6:15:00 PM	4/26/2018	5:27:00 AM	5/2/2018	<1.0	no
Water Testing	Windy Hill Elementary	6/2/2018	1	50	CS	faucet in 71	FD	4/25/2018	6:15:00 PM	4/26/2018	5:27:00 AM	5/2/2018	<1.0	no

Laboratory of MD														
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b51	CF	bubbler in 76	FD	4/25/2018	6:15:00 PM	4/26/2018	5:28:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	52	CS	faucet in 76	FD	4/25/2018	6:15:00 PM	4/26/2018	5:28:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b53	CF	bubbler in 77	FD	4/25/2018	6:15:00 PM	4/26/2018	5:22:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	54**	CS	faucet in 77	FD	4/25/2018	6:15:00 PM	4/26/2018	5:11:00 AM	5/2/2018	7.80	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b55	CF	bubbler in 78	FD	4/25/2018	6:15:00 PM	4/26/2018	5:23:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	56	CS	faucet in 78	FD	4/25/2018	6:15:00 PM	4/26/2018	5:23:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b57	CF	bubbler in 79	FD	4/25/2018	6:15:00 PM	4/26/2018	5:24:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	58	CS	faucet in 79	FD	4/25/2018	6:15:00 PM	4/26/2018	5:24:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b59	CF	bubbler in 81	FD	4/25/2018	6:15:00 PM	4/26/2018	5:26:00 AM	5/2/2018	<1.0	no

Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	60	CS	faucet in 81	FD	4/25/2018	6:15:00 PM	4/26/2018	5:26:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b61	CF	bubbler in 89	FD	4/25/2018	6:15:00 PM	4/26/2018	5:20:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	62	CS	faucet in 89	FD	4/25/2018	6:15:00 PM	4/26/2018	5:20:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b63	CF	bubbler in 90	FD	4/25/2018	6:15:00 PM	4/26/2018	5:20:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	64	CS	faucet in 90	FD	4/25/2018	6:15:00 PM	4/26/2018	5:20:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b65	CF	bubbler in 91	FD	4/25/2018	6:15:00 PM	4/26/2018	5:18:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	66	CS	faucet in 91	FD	4/25/2018	6:15:00 PM	4/26/2018	5:18:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b67	CF	bubbler in 92	FD	4/25/2018	6:15:00 PM	4/26/2018	5:17:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	68	CS	faucet in 92	FD	4/25/2018	6:15:00 PM	4/26/2018	5:17:00 AM	5/2/2018	<1.0	no
Water Testing	Windy Hill Elementary	6/2/2018	1	b69	CF	bubbler in 97	FD	4/25/2018	6:15:00 PM	4/26/2018	5:16:00 AM	5/2/2018	<1.0	no



Laboratory of MD														
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	70***	CS	faucet in 97	FD	4/25/2018	6:15:00 PM	4/26/2018	5:16:00 AM	5/2/2018	8.30	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b71	CF	bubbler in 100	FD	4/25/2018	6:15:00 PM	4/26/2018	5:14:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	72	CS	faucet in 100	FD	4/25/2018	6:15:00 PM	4/26/2018	5:14:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b73	CF	bubbler in 105	FD	4/25/2018	6:15:00 PM	4/26/2018	5:13:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	74	CS	faucet in 105	FD	4/25/2018	6:15:00 PM	4/26/2018	5:13:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	75	TL	faucet in lounge	FD	4/25/2018	6:15:00 PM	4/26/2018	5:11:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	76	CR	left faucet in 115	FD	4/25/2018	6:15:00 PM	4/26/2018	5:07:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	77	CR	right faucet in 115	FD	4/25/2018	6:15:00 PM	4/26/2018	5:07:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b78	CF	bubbler in 123	FD	4/25/2018	6:15:00 PM	4/26/2018	5:05:00 AM	5/2/2018	1.60	no

Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	79	CS	faucet in 123	FD	4/25/2018	6:15:00 PM	4/26/2018	5:15:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b80	CF	bubbler in 124	FD	4/25/2018	6:15:00 PM	4/26/2018	5:16:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	81	CS	faucet in 124	FD	4/25/2018	6:15:00 PM	4/26/2018	5:06:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	82	KS	left solo faucet in kitchen	FD	4/25/2018	6:15:00 PM	4/26/2018	5:01:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	83	KS	left faucet 3 compartment sink in kitchen	FD	4/25/2018	6:15:00 PM	4/26/2018	5:00:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	84	KS	right faucet 3 compartment sink in kitchen	FD	4/25/2018	6:15:00 PM	4/26/2018	5:00:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	85	NO	faucet in health room	FD	4/25/2018	6:15:00 PM	4/26/2018	5:38:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	86	CR	faucet in 5	FD	4/25/2018	6:15:00 PM	4/26/2018	5:38:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	87	DF	fountain outside building by 39	FD	4/25/2018	6:15:00 PM	4/26/2018	5:43:00 AM	5/2/2018	<1.0	no
Water Testing	Windy Hill Elementary	6/2/2018	1	88	IM	ice machine in kitchen	FD	4/25/2018	6:15:00 PM	4/26/2018	4:59:00 AM	5/2/2018	<1.0	no

Laboratory of MD														
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	89	IM	ice machine in right fridge/freezer combo	FD	4/25/2018	6:15:00 PM	4/26/2018	5:11:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	1	DF	fountain past main office	FD	4/25/2018	6:15:00 PM	4/26/2018	5:08:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	2	DF	fountain between 27 and 46	FD	4/25/2018	6:15:00 PM	4/26/2018	5:07:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	3	DF	fountain outside of gym	FD	4/25/2018	6:15:00 PM	4/26/2018	5:09:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	4	DF	fountain across from 47	FD	4/25/2018	6:15:00 PM	4/26/2018	5:20:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	5	DF	fountain across from 69	FD	4/25/2018	6:15:00 PM	4/26/2018	5:33:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	6	DF	fountain in gym	FD	4/25/2018	6:15:00 PM	4/26/2018	5:02:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	7	DF	fountain in cafeteria	FD	4/25/2018	6:15:00 PM	4/26/2018	5:03:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b8	CF	bubbler in 24	FD	4/25/2018	6:15:00 PM	4/26/2018	4:59:00 AM	5/2/2018	<1.0	no

Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	9	CS	fountain in 24	FD	4/25/2018	6:15:00 PM	4/26/2018	4:59:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b10	CF	bubbler in 25	FD	4/25/2018	6:15:00 PM	4/26/2018	5:01:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	11	CS	fountain in 25	FD	4/25/2018	6:15:00 PM	4/26/2018	5:01:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b12	CF	bubbler in 26	FD	4/25/2018	6:15:00 PM	4/26/2018	5:03:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	13	CS	faucet in 26	FD	4/25/2018	6:15:00 PM	4/26/2018	5:03:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b14	CF	bubbler in 27	FD	4/25/2018	6:15:00 PM	4/26/2018	5:04:00 AM	5/2/2018	1.40	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	15	CS	faucet in 27	FD	4/25/2018	6:15:00 PM	4/26/2018	5:04:00 AM	5/2/2018	1.80	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b16	CF	bubbler in 42	FD	4/25/2018	6:15:00 PM	4/26/2018	5:10:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	17	CS	faucet in 42	FD	4/25/2018	6:15:00 PM	4/26/2018	5:10:00 AM	5/2/2018	<1.0	no
Water Testing	Windy Hill Elementary	6/2/2018	1	b18	CF	bubbler in 43	FD	4/25/2018	6:15:00 PM	4/26/2018	5:12:00 AM	5/2/2018	4.00	no

Laboratory of MD														
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	19	CS	faucet in 43	FD	4/25/2018	6:15:00 PM	4/26/2018	5:12:00 AM	5/2/2018	2.40	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b20	CF	bubbler in 44	FD	4/25/2018	6:15:00 PM	4/26/2018	5:13:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	21	CS	faucet in 44	FD	4/25/2018	6:15:00 PM	4/26/2018	5:13:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b22	CF	bubbler in 45	FD	4/25/2018	6:15:00 PM	4/26/2018	5:13:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	23	CS	faucet in 45	FD	4/25/2018	6:15:00 PM	4/26/2018	5:15:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b24	CF	bubble in 46	FD	4/25/2018	6:15:00 PM	4/26/2018	5:18:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	25	CS	faucet in 46	FD	4/25/2018	6:15:00 PM	4/26/2018	5:18:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	26	CR	faucet in 29	FD	4/25/2018	6:15:00 PM	4/26/2018	5:19:00 AM	5/2/2018	1.80	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b27	CF	bubbler in 47	FD	4/25/2018	6:15:00 PM	4/26/2018	5:21:00 AM	5/2/2018	<1.0	no

Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	28	CS	faucet in 47	FD	4/25/2018	6:15:00 PM	4/26/2018	5:21:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b29	CF	bubbler in 48	FD	4/25/2018	6:15:00 PM	4/26/2018	5:23:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	30	CS	faucet in 48	FD	4/25/2018	6:15:00 PM	4/26/2018	5:23:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b31	CF	bubbler in 49	FD	4/25/2018	6:15:00 PM	4/26/2018	5:24:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	32	CS	faucet in 49	FD	4/25/2018	6:15:00 PM	4/26/2018	5:24:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b33	CF	bubbler in 50	FD	4/25/2018	6:15:00 PM	4/26/2018	5:27:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	34	CS	faucet in 50	FD	4/25/2018	6:15:00 PM	4/26/2018	5:27:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b35	CF	bubbler in 51	FD	4/25/2018	6:15:00 PM	4/26/2018	5:29:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	36	CS	faucet in 51	FD	4/25/2018	6:15:00 PM	4/26/2018	5:29:00 AM	5/2/2018	<1.0	no
Water Testing	Windy Hill Elementary	6/2/2018	2	b37	CF	bubbler in 201	FD	4/25/2018	6:15:00 PM	4/26/2018	5:30:00 AM	5/2/2018	<1.0	no

Laboratory of MD														
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	2	38	CS	faucet in 201	FD	4/25/2018	6:15:00 PM	4/26/2018	5:30:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	2	b39	CF	bubbler in 202	FD	4/25/2018	6:15:00 PM	4/26/2018	5:33:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	2	40	CS	faucet in 202	FD	4/25/2018	6:15:00 PM	4/26/2018	5:33:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b41	CF	bubbler in 60	FD	4/25/2018	6:15:00 PM	4/26/2018	5:35:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	42	CS	faucet in 60	FD	4/25/2018	6:15:00 PM	4/26/2018	5:35:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b43	CF	bubbler in 70	FD	4/25/2018	6:15:00 PM	4/26/2018	5:35:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	44*	CS	faucet in 70	FD	4/25/2018	6:15:00 PM	4/26/2018	5:35:00 AM	5/2/2018	9.00	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b45	CF	bubbler in 69	FD	4/25/2018	6:15:00 PM	4/26/2018	5:34:00 AM	5/2/2018	1.70	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	46	CS	faucet in 69	FD	4/25/2018	6:15:00 PM	4/26/2018	5:34:00 AM	5/2/2018	<1.0	no

Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b47	CF	bubbler in 72	FD	4/25/2018	6:15:00 PM	4/26/2018	5:31:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	48	CS	faucet in 72	FD	4/25/2018	6:15:00 PM	4/26/2018	5:31:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b49	CF	bubbler in 71	FD	4/25/2018	6:15:00 PM	4/26/2018	5:27:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	50	CS	faucet in 71	FD	4/25/2018	6:15:00 PM	4/26/2018	5:27:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b51	CF	bubbler in 76	FD	4/25/2018	6:15:00 PM	4/26/2018	5:28:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	52	CS	faucet in 76	FD	4/25/2018	6:15:00 PM	4/26/2018	5:28:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b53	CF	bubbler in 77	FD	4/25/2018	6:15:00 PM	4/26/2018	5:22:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	54**	CS	faucet in 77	FD	4/25/2018	6:15:00 PM	4/26/2018	5:11:00 AM	5/2/2018	7.80	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b55	CF	bubbler in 78	FD	4/25/2018	6:15:00 PM	4/26/2018	5:23:00 AM	5/2/2018	<1.0	no
Water Testing	Windy Hill Elementary	6/2/2018	1	56	CS	faucet in 78	FD	4/25/2018	6:15:00 PM	4/26/2018	5:23:00 AM	5/2/2018	<1.0	no



Laboratory of MD														
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b57	CF	bubbler in 79	FD	4/25/2018	6:15:00 PM	4/26/2018	5:24:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	58	CS	faucet in 79	FD	4/25/2018	6:15:00 PM	4/26/2018	5:24:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b59	CF	bubbler in 81	FD	4/25/2018	6:15:00 PM	4/26/2018	5:26:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	60	CS	faucet in 81	FD	4/25/2018	6:15:00 PM	4/26/2018	5:26:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b61	CF	bubbler in 89	FD	4/25/2018	6:15:00 PM	4/26/2018	5:20:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	62	CS	faucet in 89	FD	4/25/2018	6:15:00 PM	4/26/2018	5:20:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b63	CF	bubbler in 90	FD	4/25/2018	6:15:00 PM	4/26/2018	5:20:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	64	CS	faucet in 90	FD	4/25/2018	6:15:00 PM	4/26/2018	5:20:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b65	CF	bubbler in 91	FD	4/25/2018	6:15:00 PM	4/26/2018	5:18:00 AM	5/2/2018	<1.0	no

Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	66	CS	faucet in 91	FD	4/25/2018	6:15:00 PM	4/26/2018	5:18:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b67	CF	bubbler in 92	FD	4/25/2018	6:15:00 PM	4/26/2018	5:17:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	68	CS	faucet in 92	FD	4/25/2018	6:15:00 PM	4/26/2018	5:17:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b69	CF	bubbler in 97	FD	4/25/2018	6:15:00 PM	4/26/2018	5:16:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	70***	CS	faucet in 97	FD	4/25/2018	6:15:00 PM	4/26/2018	5:16:00 AM	5/2/2018	8.30	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b71	CF	bubbler in 100	FD	4/25/2018	6:15:00 PM	4/26/2018	5:14:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	72	CS	faucet in 100	FD	4/25/2018	6:15:00 PM	4/26/2018	5:14:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b73	CF	bubbler in 105	FD	4/25/2018	6:15:00 PM	4/26/2018	5:13:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	74	CS	faucet in 105	FD	4/25/2018	6:15:00 PM	4/26/2018	5:13:00 AM	5/2/2018	<1.0	no
Water Testing	Windy Hill Elementary	6/2/2018	1	75	TL	faucet in lounge	FD	4/25/2018	6:15:00 PM	4/26/2018	5:11:00 AM	5/2/2018	<1.0	no

Laboratory of MD														
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	76	CR	left faucet in 115	FD	4/25/2018	6:15:00 PM	4/26/2018	5:07:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	77	CR	right faucet in 115	FD	4/25/2018	6:15:00 PM	4/26/2018	5:07:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b78	CF	bubbler in 123	FD	4/25/2018	6:15:00 PM	4/26/2018	5:05:00 AM	5/2/2018	1.60	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	79	CS	faucet in 123	FD	4/25/2018	6:15:00 PM	4/26/2018	5:15:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	b80	CF	bubbler in 124	FD	4/25/2018	6:15:00 PM	4/26/2018	5:16:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	81	CS	faucet in 124	FD	4/25/2018	6:15:00 PM	4/26/2018	5:06:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	82	KS	left solo faucet in kitchen	FD	4/25/2018	6:15:00 PM	4/26/2018	5:01:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	83	KS	left faucet 3 compartment sink in kitchen	FD	4/25/2018	6:15:00 PM	4/26/2018	5:00:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	84	KS	right faucet 3 compartment sink in kitchen	FD	4/25/2018	6:15:00 PM	4/26/2018	5:00:00 AM	5/2/2018	<1.0	no

Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	85	NO	faucet in health room	FD	4/25/2018	6:15:00 PM	4/26/2018	5:38:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	86	CR	faucet in 5	FD	4/25/2018	6:15:00 PM	4/26/2018	5:38:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	87	DF	fountain outside building by 39	FD	4/25/2018	6:15:00 PM	4/26/2018	5:43:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	88	IM	ice machine in kitchen	FD	4/25/2018	6:15:00 PM	4/26/2018	4:59:00 AM	5/2/2018	<1.0	no
Water Testing Laboratory of MD	Windy Hill Elementary	6/2/2018	1	89	IM	ice machine in right fridge/freezer combo	FD	4/25/2018	6:15:00 PM	4/26/2018	5:11:00 AM	5/2/2018	<1.0	no