

# Windy Hill Middle School

## 2018-2019 Testing Results

Laboratory Name	School Name	Laboratory Reporting Date	Floor #	School Outlet ID/Floor Plan ID	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Description/Location	Sample Type (Code)	Date Water Last Used	Time Water Last Used	Date Sample Collected	Time Sample Collected	Analysis Date	Lead Sample Result (ppb)	≥ 20.5 ppb AL?
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	1	DF	left fountain outside of office	FD	3/20/2019	8:00:00 PM	3/21/2019	5:23:00 AM	3/23/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	2	DF	right fountain outside of office	FD	3/20/2019	8:00:00 PM	3/21/2019	5:23:00 AM	3/23/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	3	DF	left fountain outside gym	FD	3/20/2019	8:00:00 PM	3/21/2019	5:30:00 AM	3/23/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	4	DF	right fountain outside gym	FD	3/20/2019	8:00:00 PM	3/21/2019	5:30:00 AM	3/23/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	5	DF	left fountain in boys locker room	FD	3/20/2019	8:00:00 PM	3/21/2019	5:42:00 AM	3/23/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	6	DF	right fountain in boys locker room	FD	3/20/2019	8:00:00 PM	3/21/2019	5:42:00 AM	3/23/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	7	DF	left fountain in boys locker room	FD	3/20/2019	8:00:00 PM	3/21/2019	5:41:00 AM	3/23/2019	<1.0	No

Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	8	DF	right fountain in boys locker room	FD	3/20/2019	8:00:00 PM	3/21/2019	5:41:00 AM	3/23/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	9	DF	left fountain outside 117	FD	3/20/2019	8:00:00 PM	3/21/2019	5:44:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	10	DF	right fountain outside 117	FD	3/20/2019	8:00:00 PM	3/21/2019	5:44:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	11	DF	left fountain outside 126	FD	3/20/2019	8:00:00 PM	3/21/2019	5:46:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	12	DF	right fountain outside 126	FD	3/20/2019	8:00:00 PM	3/21/2019	5:46:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	2	13	DF	left fountain outside 222	FD	3/20/2019	8:00:00 PM	3/21/2019	5:25:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	2	14	DF	right fountain outside 222	FD	3/20/2019	8:00:00 PM	3/21/2019	5:25:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	15	CR	faucet in office work room	FD	3/20/2019	8:00:00 PM	3/21/2019	5:18:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	16	NO	faucet in health room	FD	3/20/2019	8:00:00 PM	3/21/2019	5:18:00 AM	3/24/2019	<1.0	No
Water Testing	Windy Hill Middle School	4/6/2019	1	17	IM	ice machine in health room	FD	3/20/2019	8:00:00 PM	3/21/2019	5:20:00 AM	3/24/2019	<1.0	No

Laboratory of MD														
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	18	TL	faucet in staff lounge	FD	3/20/2019	8:00:00 PM	3/21/2019	5:27:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	19	CR	faucet in 107	FD	3/20/2019	8:00:00 PM	3/21/2019	5:26:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	20	CR	faucet in 109	FD	3/20/2019	8:00:00 PM	3/21/2019	5:25:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	21	IM	ice machine in kitchen	FD	3/20/2019	8:00:00 PM	3/21/2019	5:32:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	22	KS	solo faucet on prep table	FD	3/20/2019	8:00:00 PM	3/21/2019	5:33:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	23	KS	faucet on 2 compartment sink	FD	3/20/2019	8:00:00 PM	3/21/2019	5:34:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	24	KS	sprayer on 2 compartment sink	FD	3/20/2019	8:00:00 PM	3/21/2019	5:34:00 AM	3/24/2019	1.6	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	25	KS	left kettle	FD	3/20/2019	8:00:00 PM	3/21/2019	5:35:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	26	KS	right kettle	FD	3/20/2019	8:00:00 PM	3/21/2019	5:35:00 AM	3/24/2019	1.1	No

Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	27	KS	left faucet 3 compartment sink	FD	3/20/2019	8:00:00 PM	3/21/2019	5:36:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	28	KS	right faucet 3 compartment sink	FD	3/20/2019	8:00:00 PM	3/21/2019	5:36:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	29	KS	dish washer sprayer	FD	3/20/2019	8:00:00 PM	3/21/2019	5:37:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	30	HE	front left faucet 115	FD	3/20/2019	8:00:00 PM	3/21/2019	5:35:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	31	HE	front right faucet 115	FD	3/20/2019	8:00:00 PM	3/21/2019	5:35:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	32	IM	ice machine in front right fridge	FD	3/20/2019	8:00:00 PM	3/21/2019	5:35:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	33	HE	middle left faucet 115	FD	3/20/2019	8:00:00 PM	3/21/2019	5:36:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	34	HE	middle right faucet 115	FD	3/20/2019	8:00:00 PM	3/21/2019	5:36:00 AM	3/24/2019	1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	35	HE	back left faucet 115	FD	3/20/2019	8:00:00 PM	3/21/2019	5:37:00 AM	3/24/2019	<1.0	No
Water Testing	Windy Hill Middle School	4/6/2019	1	36	HE	back right faucet 115	FD	3/20/2019	8:00:00 PM	3/21/2019	5:37:00 AM	3/24/2019	<1.0	No

Laboratory of MD														
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	37	IM	ice machine in back right fridge	FD	3/20/2019	8:00:00 PM	3/21/2019	5:38:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	38	HE	teacher prep faucet	FD	3/20/2019	8:00:00 PM	3/21/2019	5:38:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	39	CR	left faucet 119	FD	3/20/2019	8:00:00 PM	3/21/2019	5:33:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	40	CR	right faucet 119	FD	3/20/2019	8:00:00 PM	3/21/2019	5:33:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	41	CR	faucet 118	FD	3/20/2019	8:00:00 PM	3/21/2019	5:32:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	42	CR	faucet in 122	FD	3/20/2019	8:00:00 PM	3/21/2019	5:30:00 AM	3/24/2019	1.1	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	43	CR	faucet in media center work room	FD	3/20/2019	8:00:00 PM	3/21/2019	5:29:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	2	44	CR	faucet in 211	FD	3/20/2019	8:00:00 PM	3/21/2019	5:21:00 AM	3/24/2019	1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	2	45	DF	left fountain outside 210	FD	3/20/2019	8:00:00 PM	3/21/2019	5:22:00 AM	3/24/2019	<1.0	No

Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	2	46	DF	right fountain outside 210	FD	3/20/2019	8:00:00 PM	3/21/2019	5:22:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	2	47	CR	faucet in 209	FD	3/20/2019	8:00:00 PM	3/21/2019	5:20:00 AM	3/24/2019	2.2	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	2	48	CR	faucet in project room by 224	FD	3/20/2019	8:00:00 PM	3/21/2019	5:26:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	2	49	CR	faucet 221	FD	3/20/2019	8:00:00 PM	3/21/2019	5:26:00 AM	3/24/2019	1.6	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	1	DF	left fountain outside of office	FD	3/20/2019	8:00:00 PM	3/21/2019	5:23:00 AM	3/23/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	2	DF	right fountain outside of office	FD	3/20/2019	8:00:00 PM	3/21/2019	5:23:00 AM	3/23/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	3	DF	left fountain outside gym	FD	3/20/2019	8:00:00 PM	3/21/2019	5:30:00 AM	3/23/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	4	DF	right fountain outside gym	FD	3/20/2019	8:00:00 PM	3/21/2019	5:30:00 AM	3/23/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	5	DF	left fountain in boys locker room	FD	3/20/2019	8:00:00 PM	3/21/2019	5:42:00 AM	3/23/2019	<1.0	No
Water Testing	Windy Hill Middle School	4/6/2019	1	6	DF	right fountain in boys locker room	FD	3/20/2019	8:00:00 PM	3/21/2019	5:42:00 AM	3/23/2019	<1.0	No

Laboratory of MD														
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	7	DF	left fountain in boys locker room	FD	3/20/2019	8:00:00 PM	3/21/2019	5:41:00 AM	3/23/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	8	DF	right fountain in boys locker room	FD	3/20/2019	8:00:00 PM	3/21/2019	5:41:00 AM	3/23/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	9	DF	left fountain outside 117	FD	3/20/2019	8:00:00 PM	3/21/2019	5:44:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	10	DF	right fountain outside 117	FD	3/20/2019	8:00:00 PM	3/21/2019	5:44:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	11	DF	left fountain outside 126	FD	3/20/2019	8:00:00 PM	3/21/2019	5:46:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	12	DF	right fountain outside 126	FD	3/20/2019	8:00:00 PM	3/21/2019	5:46:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	2	13	DF	left fountain outside 222	FD	3/20/2019	8:00:00 PM	3/21/2019	5:25:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	2	14	DF	right fountain outside 222	FD	3/20/2019	8:00:00 PM	3/21/2019	5:25:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	15	CR	faucet in office work room	FD	3/20/2019	8:00:00 PM	3/21/2019	5:18:00 AM	3/24/2019	<1.0	No

Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	16	NO	faucet in health room	FD	3/20/2019	8:00:00 PM	3/21/2019	5:18:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	17	IM	ice machine in health room	FD	3/20/2019	8:00:00 PM	3/21/2019	5:20:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	18	TL	faucet in staff lounge	FD	3/20/2019	8:00:00 PM	3/21/2019	5:27:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	19	CR	faucet in 107	FD	3/20/2019	8:00:00 PM	3/21/2019	5:26:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	20	CR	faucet in 109	FD	3/20/2019	8:00:00 PM	3/21/2019	5:25:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	21	IM	ice machine in kitchen	FD	3/20/2019	8:00:00 PM	3/21/2019	5:32:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	22	KS	solo faucet on prep table	FD	3/20/2019	8:00:00 PM	3/21/2019	5:33:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	23	KS	faucet on 2 compartment sink	FD	3/20/2019	8:00:00 PM	3/21/2019	5:34:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	24	KS	sprayer on 2 compartment sink	FD	3/20/2019	8:00:00 PM	3/21/2019	5:34:00 AM	3/24/2019	1.6	No
Water Testing	Windy Hill Middle School	4/6/2019	1	25	KS	left kettle	FD	3/20/2019	8:00:00 PM	3/21/2019	5:35:00 AM	3/24/2019	<1.0	No



Laboratory of MD														
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	26	KS	right kettle	FD	3/20/2019	8:00:00 PM	3/21/2019	5:35:00 AM	3/24/2019	1.1	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	27	KS	left faucet 3 compartment sink	FD	3/20/2019	8:00:00 PM	3/21/2019	5:36:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	28	KS	right faucet 3 compartment sink	FD	3/20/2019	8:00:00 PM	3/21/2019	5:36:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	29	KS	dish washer sprayer	FD	3/20/2019	8:00:00 PM	3/21/2019	5:37:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	30	HE	front left faucet 115	FD	3/20/2019	8:00:00 PM	3/21/2019	5:35:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	31	HE	front right faucet 115	FD	3/20/2019	8:00:00 PM	3/21/2019	5:35:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	32	IM	ice machine in front right fridge	FD	3/20/2019	8:00:00 PM	3/21/2019	5:35:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	33	HE	middle left faucet 115	FD	3/20/2019	8:00:00 PM	3/21/2019	5:36:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	34	HE	middle right faucet 115	FD	3/20/2019	8:00:00 PM	3/21/2019	5:36:00 AM	3/24/2019	1.0	No

Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	35	HE	back left faucet 115	FD	3/20/2019	8:00:00 PM	3/21/2019	5:37:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	36	HE	back right faucet 115	FD	3/20/2019	8:00:00 PM	3/21/2019	5:37:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	37	IM	ice machine in back right fridge	FD	3/20/2019	8:00:00 PM	3/21/2019	5:38:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	38	HE	teacher prep faucet	FD	3/20/2019	8:00:00 PM	3/21/2019	5:38:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	39	CR	left faucet 119	FD	3/20/2019	8:00:00 PM	3/21/2019	5:33:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	40	CR	right faucet 119	FD	3/20/2019	8:00:00 PM	3/21/2019	5:33:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	41	CR	faucet 118	FD	3/20/2019	8:00:00 PM	3/21/2019	5:32:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	42	CR	faucet in 122	FD	3/20/2019	8:00:00 PM	3/21/2019	5:30:00 AM	3/24/2019	1.1	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	43	CR	faucet in media center work room	FD	3/20/2019	8:00:00 PM	3/21/2019	5:29:00 AM	3/24/2019	<1.0	No
Water Testing	Windy Hill Middle School	4/6/2019	2	44	CR	faucet in 211	FD	3/20/2019	8:00:00 PM	3/21/2019	5:21:00 AM	3/24/2019	1.0	No

Laboratory of MD														
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	2	45	DF	left fountain outside 210	FD	3/20/2019	8:00:00 PM	3/21/2019	5:22:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	2	46	DF	right fountain outside 210	FD	3/20/2019	8:00:00 PM	3/21/2019	5:22:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	2	47	CR	faucet in 209	FD	3/20/2019	8:00:00 PM	3/21/2019	5:20:00 AM	3/24/2019	2.2	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	2	48	CR	faucet in project room by 224	FD	3/20/2019	8:00:00 PM	3/21/2019	5:26:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	2	49	CR	faucet 221	FD	3/20/2019	8:00:00 PM	3/21/2019	5:26:00 AM	3/24/2019	1.6	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	1	DF	left fountain outside of office	FD	3/20/2019	8:00:00 PM	3/21/2019	5:23:00 AM	3/23/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	2	DF	right fountain outside of office	FD	3/20/2019	8:00:00 PM	3/21/2019	5:23:00 AM	3/23/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	3	DF	left fountain outside gym	FD	3/20/2019	8:00:00 PM	3/21/2019	5:30:00 AM	3/23/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	4	DF	right fountain outside gym	FD	3/20/2019	8:00:00 PM	3/21/2019	5:30:00 AM	3/23/2019	<1.0	No

Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	5	DF	left fountain in boys locker room	FD	3/20/2019	8:00:00 PM	3/21/2019	5:42:00 AM	3/23/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	6	DF	right fountain in boys locker room	FD	3/20/2019	8:00:00 PM	3/21/2019	5:42:00 AM	3/23/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	7	DF	left fountain in boys locker room	FD	3/20/2019	8:00:00 PM	3/21/2019	5:41:00 AM	3/23/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	8	DF	right fountain in boys locker room	FD	3/20/2019	8:00:00 PM	3/21/2019	5:41:00 AM	3/23/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	9	DF	left fountain outside 117	FD	3/20/2019	8:00:00 PM	3/21/2019	5:44:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	10	DF	right fountain outside 117	FD	3/20/2019	8:00:00 PM	3/21/2019	5:44:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	11	DF	left fountain outside 126	FD	3/20/2019	8:00:00 PM	3/21/2019	5:46:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	12	DF	right fountain outside 126	FD	3/20/2019	8:00:00 PM	3/21/2019	5:46:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	2	13	DF	left fountain outside 222	FD	3/20/2019	8:00:00 PM	3/21/2019	5:25:00 AM	3/24/2019	<1.0	No
Water Testing	Windy Hill Middle School	4/6/2019	2	14	DF	right fountain outside 222	FD	3/20/2019	8:00:00 PM	3/21/2019	5:25:00 AM	3/24/2019	<1.0	No

Laboratory of MD														
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	15	CR	faucet in office work room	FD	3/20/2019	8:00:00 PM	3/21/2019	5:18:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	16	NO	faucet in health room	FD	3/20/2019	8:00:00 PM	3/21/2019	5:18:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	17	IM	ice machine in health room	FD	3/20/2019	8:00:00 PM	3/21/2019	5:20:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	18	TL	faucet in staff lounge	FD	3/20/2019	8:00:00 PM	3/21/2019	5:27:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	19	CR	faucet in 107	FD	3/20/2019	8:00:00 PM	3/21/2019	5:26:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	20	CR	faucet in 109	FD	3/20/2019	8:00:00 PM	3/21/2019	5:25:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	21	IM	ice machine in kitchen	FD	3/20/2019	8:00:00 PM	3/21/2019	5:32:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	22	KS	solo faucet on prep table	FD	3/20/2019	8:00:00 PM	3/21/2019	5:33:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	23	KS	faucet on 2 compartment sink	FD	3/20/2019	8:00:00 PM	3/21/2019	5:34:00 AM	3/24/2019	<1.0	No

Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	24	KS	sprayer on 2 compartment sink	FD	3/20/2019	8:00:00 PM	3/21/2019	5:34:00 AM	3/24/2019	1.6	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	25	KS	left kettle	FD	3/20/2019	8:00:00 PM	3/21/2019	5:35:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	26	KS	right kettle	FD	3/20/2019	8:00:00 PM	3/21/2019	5:35:00 AM	3/24/2019	1.1	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	27	KS	left faucet 3 compartment sink	FD	3/20/2019	8:00:00 PM	3/21/2019	5:36:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	28	KS	right faucet 3 compartment sink	FD	3/20/2019	8:00:00 PM	3/21/2019	5:36:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	29	KS	dish washer sprayer	FD	3/20/2019	8:00:00 PM	3/21/2019	5:37:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	30	HE	front left faucet 115	FD	3/20/2019	8:00:00 PM	3/21/2019	5:35:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	31	HE	front right faucet 115	FD	3/20/2019	8:00:00 PM	3/21/2019	5:35:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	32	IM	ice machine in front right fridge	FD	3/20/2019	8:00:00 PM	3/21/2019	5:35:00 AM	3/24/2019	<1.0	No
Water Testing	Windy Hill Middle School	4/6/2019	1	33	HE	middle left faucet 115	FD	3/20/2019	8:00:00 PM	3/21/2019	5:36:00 AM	3/24/2019	<1.0	No

Laboratory of MD														
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	34	HE	middle right faucet 115	FD	3/20/2019	8:00:00 PM	3/21/2019	5:36:00 AM	3/24/2019	1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	35	HE	back left faucet 115	FD	3/20/2019	8:00:00 PM	3/21/2019	5:37:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	36	HE	back right faucet 115	FD	3/20/2019	8:00:00 PM	3/21/2019	5:37:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	37	IM	ice machine in back right fridge	FD	3/20/2019	8:00:00 PM	3/21/2019	5:38:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	38	HE	teacher prep faucet	FD	3/20/2019	8:00:00 PM	3/21/2019	5:38:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	39	CR	left faucet 119	FD	3/20/2019	8:00:00 PM	3/21/2019	5:33:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	40	CR	right faucet 119	FD	3/20/2019	8:00:00 PM	3/21/2019	5:33:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	41	CR	faucet 118	FD	3/20/2019	8:00:00 PM	3/21/2019	5:32:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	42	CR	faucet in 122	FD	3/20/2019	8:00:00 PM	3/21/2019	5:30:00 AM	3/24/2019	1.1	No

Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	1	43	CR	faucet in media center work room	FD	3/20/2019	8:00:00 PM	3/21/2019	5:29:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	2	44	CR	faucet in 211	FD	3/20/2019	8:00:00 PM	3/21/2019	5:21:00 AM	3/24/2019	1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	2	45	DF	left fountain outside 210	FD	3/20/2019	8:00:00 PM	3/21/2019	5:22:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	2	46	DF	right fountain outside 210	FD	3/20/2019	8:00:00 PM	3/21/2019	5:22:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	2	47	CR	faucet in 209	FD	3/20/2019	8:00:00 PM	3/21/2019	5:20:00 AM	3/24/2019	2.2	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	2	48	CR	faucet in project room by 224	FD	3/20/2019	8:00:00 PM	3/21/2019	5:26:00 AM	3/24/2019	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/6/2019	2	49	CR	faucet 221	FD	3/20/2019	8:00:00 PM	3/21/2019	5:26:00 AM	3/24/2019	1.6	No